

ADVERTISEMENT FOR POLYMER BIDS

SEPARATE SEALED BIDS FOR THE PURCHASE OF POLYMER FOR A POTABLE WATER TREATMENT PLANT OF 18 MGD CAPACITY WILL BE RECEIVED BY THE NORTHEAST MISSISSIPPI REGIONAL WATER SUPPLY DISTRICT, POST OFFICE BOX 111, FULTON, MS 38843 / FEDEX ADDRESS 5590 HWY 178 WEST, FULTON MS 38843, UNTIL 11 AM CENTRAL TIME, MARCH 16TH, 2023, **SEALED BIDS FOR POLYMER WILL BE OPENED, MARCH 16TH, 2023 AT 11 AM AND REVIEWED AT THE TREATMENT PLANT ADDRESS 5590 HWY 178 WEST, FULTON, MS 38843 PHONE 662-862-7045.** THESE BIDS WILL BE SUBMITTED FOR APPROVAL AT THE MEETING OF THE DISTRICT BOARD ON MARCH 23RD, 2023.

ALL BIDS MUST BE SUBMITTED IN A SEALED ENVELOPE ADDRESSED TO THE NORTHEAST MISSISSIPPI REGIONAL WATER SUPPLY DISTRICT. EACH SEALED ENVELOPE CONTAINING A BID MUST BE PLAINLY MARKED ON THE OUTSIDE AS **"BID FOR POLMER TO BE OPENED MARCH 16TH, 2023."**

BID PRICES WILL BE F.O.B. TO THE NORTHEAST MISSISSIPPI REGIONAL WATER TREATMENT PLANT, 5590 HWY 178 WEST, FULTON, MS 38843. THE NORTHEAST MISSISSIPPI REGIONAL WATER SUPPLY DISTRICT RESERVES THE RIGHT TO ACCEPT ALTERNATE BIDS IN THE EVENT THE PRIMARY SUPPLIER IS UNABLE TO PROVIDE PRODUCT AS SPECIFIED.

POLYMER MUST BE ANSI/NSF STANDARD 60 APPROVED. ALL VENDORS SHALL PROVIDE CERTIFICATE OF ANSI/NSF STANDARD 60 APPROVALS. THIS SHALL BE SUBMITTED WITH YOUR BID. THE BID SHALL BE ON A BULK BASIS AND MATERIAL SHALL MEET THE FOLLOWING SPECIFICATIONS:

1. LIQUID POLYMER - TOTES

Polymer shall be liquid, 20% active. Material shall be capable of sludge blanket control over all expected temperature ranges. Material shall meet all **AWWA** standards for potable water. The polymer must blend with the district's house water to form a 0.5 to 3% solution of polymer or the polymer will be deemed unacceptable. Bidders shall have completed a successful pilot plant study using at least 500 lbs. of their product for testing in the district's process before bid acceptance.

Delivery

Delivery of the polymer shall be within 10 calendar days of notification of the order. Packaging and shipping the polymer shall conform to all applicable federal, state, and local regulations. Net weight error shall conform to the national

bureau of standards- shipment shall contain no less than 98 percent of the stated weight.

POLYMER TO BE BID DELIVERED TO THE PLANT SITE IN PEPPERTOWN, MISSISSIPPI. DELIVERY TIMES RECONGNIZED AT THE PLANT WILL BE MONDAY - FRIDAY, 8 AM TO 4 PM. SIZE OF ORDERS WILL BE BASED ON AVAILABLE STORAGE AT THE PLANT. **ALL PRICES SHALL BE FOR BULK QUANTITIES AND SAID PRICES SHALL REMAIN CONSTANT FOR A PERIOD OF THREE CALENDAR MONTHS, APRIL 1ST, 2023 THRU JUNE 30TH, 2023, FOLLOWING THE ACCEPTANCE OF THE BIDS. THE DISTRICT SHALL NOT RECOGNIZE ANY MODIFICATIONS TO THE PRICE OF THE CHEMICALS DURING QUARTER, INCLUDING BUT NOT LIMITED TO FUEL SURCHARGES AND OTHER CHARGES.** INVOICES RECEIVED AFTER THE THIRD WEDNESDAY OF THE MONTH, WILL BE PAID THE FOLLOWING MONTH. THE DISTRICT RESERVES THE RIGHT TO REJECT ANY AND ALL BIDS.

ANY QUESTIONS CONCERNING THE QUANTITIES OR OTHER SPECIFICATIONS HEREIN SHOULD BE MADE TO MELVIN ORR, VEOLIA WATER NORTH AMERICA, POST OFFICE BOX 111, FULTON, MISSISSIPPI, 38843, TELEPHONE (662)-862-7045.

DONE BY THE NORTHEAST MISSISSIPPI REGIONAL WATER SUPPLY DISTRICT THIS, THE 26th , DAY OF JANUARY 2023.

RONNIE BELL, CHAIRMAN

PUBLISH: February 15th and 22th , 2023