

**ADDENDUM NUMBER ONE (1)**  
**CITY OF HORN LAKE**  
**TWIN LAKES WATER IMPROVEMENTS DISTRIBUTION LINES**

**April 17, 2023**

To all Prospective Bidders for the Project described above for which bids are to be received by the City of Horn Lake 3101 Goodman Road West, Horn Lake, MS 38637 until 11:00 AM local time, Monday, April 17, 2023.

Bidders are to note the following items/clarifications to the Plan Documents:

1. **SHEET C100- PLEASE REMOVE THE REFERENCE TO "RE-ESTABLISH CROSS-CONNECTION PIV REQ'D 12" X 8" TEE CUT-IN SLEEVE AT STATION 22+60."**
2. **SHEET C101- PLEASE ADD A NOTE AT WATERLINE TIE AT STATION 48+00 "CONNECT TO EXISTING 4" LINE". THIS IS THE SAME NOTE AS AT STATION 44+50.**
  - a. **(2) 12" X 4" TEE,**
  - b. **4" VALVE AND BOX,**
  - c. **4" 90 DEGREE BEND,**
  - d. **4" TEE, 4" CUT-IN SLEEVE**
  - e. **(2) 4" PLUGS**
3. **SHEET C102- PLEASE CHANGE 12" PIPE TO 8" PIPE ON THE NOTE AT STATION 18+00." THE NOTE SHOULD READ.=**
  - a. **(2) 8" VALVE AND BOX**
  - b. **(1) 8" X 6" TEE**
4. **SHEET C102- PLEASE CHANGE 12" PIPE TO 8" PIPE ON THE NOTE AT STATION 30+20." THE NOTE SHOULD READ.**
  - a. **(2) 8" VALVE AND BOX**
  - b. **(1) 8" X 6" TEE**

On the Bid Form, the Prospective Bidders shall be reminded to acknowledge **ADDENDUM NUMBER 1** by completing the bidder acknowledges of receipt on page 00300-6.