

**FEMA HAZARD MITIGATION GRANT PROJECT NO. 4415-8  
SOUTH LAMAR BOULEVARD BOX BRIDGE  
IMPROVEMENT PROJECT  
CLARIFICATION NO. 1**

CLARIFICATION FOR CONTRACT PLANS

1. **Contract Plans**

A. **PLAN & PROFILE—SHEET 3**

For Clarity – The plans indicate that the existing sewer casing pipe and support stands on the east side of South Lamar Boulevard will be relocated by others. For the purposes of the bid proposal, the prospective bidder should anticipate that the sewer casing pipe and support stands will not be relocated and that it will need to be formed and built around into the proposed wingwalls and apron. Any cost adjustments that the proposed contractor should have associated with this should be included within the existing pay items already set up for this project.

All provisions of the Contract Documents and Contract Drawings shall remain unchanged and in full effect.

This is a clarification, not an Addendum; therefore, it does not have to be turned in with your bid

DATE: June 9, 2023



Jimmy Catt Jr., PE  
Project Engineer

RECEIVED:

The recipient of this Clarification shall indicate receipt thereof by his signature below.

DATE: \_\_\_\_\_

\_\_\_\_\_  
Signed: Company Representative