



March 14, 2018

Re: 18-14, Addendum #1, Raspet Building Oven Installation and Fabrication

To Whom It May Concern:

1Q) Paragraph 2.21: Are the interior vacuum stabs shut off valves required to be automated or manual ball valves?

1A) manual

2Q) Paragraph 2.22: Who is responsible to provide and install exhaust ducts (stacks from the oven chambers)?

2A) oven equipment supplier

3Q) Paragraph 2.22: Who is responsible to provide roof or wall penetrations for the exhaust ducts or stacks?

3A) Oven equipment supplier

4Q) Paragraph 3.7: Please clarify on the drawing where the locations for electric and air service are in the building vs. oven installation location? The drawings provided are not clear and we cannot determine location of these utility locations?

4A) The university will provide/route the utilities to the location required for the oven defined by the oven manufacture.

5Q) Paragraph 3.7: What about gas supply. Who is responsible for the gas connections to oven gas trains? What is the gas pressure available? Where is the gas connection location in the building?

5A) The University will supply the required gas service to the oven. Requirements for the gas oven will be defined by the oven manufacture.

6Q) What are the proposed payment terms?

6A) 45 days

7Q) What is the required delivery?

7A) We need the oven as soon as possible.

**Addendum: Acknowledge the receipt of each addendum by writing on the bid form the number of the addendum and the date received.**

Thank you,

A handwritten signature in cursive script that reads "Debra Raines". The signature is written in dark ink and is positioned above the printed name and title.

Debra Raines  
Bid Specialist