

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Hydraulic - Elevator or Dumbwaiter**

Date of Inspection: 07/17/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649748

Building Location and Unit Information

Building Name:	DFA 620 BUILDING	MS Unit ID Number:	MS006113	Unit Designation:	1
Address:	620 NORTH ST. STREET	Manufacturer:	Otis	Installed Year:	1977
City, State, Zip:	JACKSON MS 39201	Speed:	125 fpm	Capacity:	2500 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	2
				Openings:	2

(Continuation)

MS Unit ID Number: MS006113	Report Number: 4649748
------------------------------------	-------------------------------



1. ELEVATOR INSIDE OF CAR				Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1	Door reopening device			X			2.38 (H) Roped water hydraulic elevators	X		
1.2	Stop switches			X			2.39 (H) Low oil protection	X		
1.3	Operating control devices			X			2.40 Maintenance records	X		
1.4	Sills & car floor			X			2.41 Static control	X		
1.5	Car lighting & receptacles			X			3. ELEVATOR TOP OF CAR			
1.6	Car emergency signal-lighting				X		Pass	Fail	N/A	
1.7	Car door or gate			X			3.1 Top-of-car stop switch	X		
1.8	Door closing force			X			3.2 Car top light & outlet	X		
1.9	Power closing of doors or gates			X			3.3 Top-of-car operating device		X	
1.10	Power opening of doors or gates			X			3.4 Clearance, refuge space standard railing	X		
1.11	Car vision panels & glass car doors			X			3.5 Normal terminal stopping devices	X		
1.12	Car enclosure			X			3.6 Final & emergency terminal stopping devices	X		
1.13	Emergency exit			X			3.7 Car leveling & anti-creep devices	X		
1.14	Ventilation			X			3.8 Top emergency exit	X		
1.15	Signs & operating device symbols			X			3.9 Floor & emergency identification numbering	X		
1.16	Related load, platform area, & data plate			X			3.10 Hoist-way construction	X		
1.17	Standby power operation			X			3.11 Hoist-way smoke control (IDPH only)	X		
1.18	Restricted opening of car or hoist-way doors				X		3.12 Pipes, wiring & ducts	X		
1.19	Car ride			X			3.13 Windows, projections, recesses, & setbacks	X		
2. ELEVATOR MACHINE ROOM				Pass	Fail	N/A	3.14 Hoist-way clearances	X		
2.1	Access to Machine Space				X		3.15 Multiple hoist-ways	X		
2.2	Headroom			X			3.16 Traveling cables & junction boxes	X		
2.3	Lighting & receptacles			X			3.17 Door & gate equipment	X		
2.4	Machine space			X			3.18 Car frame & stiles	X		
2.5	Housekeeping				X		3.19 Guide rails fastening & equipment	X		
2.6	Ventilation			X			3.20 Governor rope	X		
2.7	Fire extinguisher			X			3.21 Governor releasing carrier	X		
2.8	Pipes, wiring, & ducts			X			3.22 Wire rope fastening & hitch plate	X		
2.9	Guarding of exposed auxiliary equipment			X			3.23 Suspension rope	X		
2.10	Numbering of elevators, machines, disconnects			X			3.27 Crosshead data plate & rope data tags	X		
2.11	Disconnecting means & control				X		3.28 Counterweight & counterweight bu er	X		
2.12	Controller wiring, fuses, grounding, etc.			X			3.29 Counterweight safeties	X		
2.13	Governor, over-speed switch, & seal			X			3.30 (H) Speed test	X		
2.14	Code data plate			X			3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.30	(H) Hydraulic power unit			X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.31	(H) Relief valves			X			4. ELEVATOR OUTSIDE HOIST-WAY			
2.32	(H) Control valve			X			Pass	Fail	N/A	
2.33	(H) Tanks			X			4.1 Car platform guard	X		
2.34	(H) Flexible hydraulic hose & fitting assemblies			X			4.2 Hoist-way doors	X		
2.35	(H) Supply line & shutoff valve				X		4.3 Vision panels	X		
2.36	(H) Hydraulic cylinders			X			4.4 Hoistway door locking devices	X		
							4.5 Access to hoist -way	X		
							4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS006113	Report Number: 4649748
------------------------------------	-------------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
1.6	X	Emergency phone not working
1.18	X	Door restriction required
2.1		Machine room door is required to be self-locking
2.1		machine room door is required to be self-closing
2.5		Remove non-elevator related materials from machine/control room/space
2.11		Provide a car light disconnect
2.11		Mainline disconnect must be fused and lockable
2.35		Shutoff valve required in machine room
3.3	X	Top-of-car operating device required
5.1	X	Repair/provide pit ladder
5.1		Pit light switch is required to be reachable from the access point and adjacent to pit ladder

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	620 N WEST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	 

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Hydraulic - Elevator or Dumbwaiter**

Date of Inspection: 07/17/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649749

Building Location and Unit Information

Building Name:	DFA 660 BUILDING	MS Unit ID Number:	MS006114	Unit Designation:	1
Address:	660 NORTH ST. STREET	Manufacturer:	Schindler	Installed Year:	2004
City, State, Zip:	JACKSON MS 39201	Speed:	100 fpm	Capacity:	3500 lbs
Contact:	DEPARTMENT OF FINANCE - 620 BLDG	Phone:	(769) 245-6329	Stops:	2
				Openings:	2

(Continuation)

MS Unit ID Number: MS006114	Report Number: 4649749
------------------------------------	-------------------------------



1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1 Door reopening device	X			2.38 (H) Roped water hydraulic elevators	X		
1.2 Stop switches	X			2.39 (H) Low oil protection	X		
1.3 Operating control devices	X			2.40 Maintenance records	X		
1.4 Sills & car floor	X			2.41 Static control	X		
1.5 Car lighting & receptacles	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.6 Car emergency signal-lighting	X			3.1 Top-of-car stop switch	X		
1.7 Car door or gate	X			3.2 Car top light & outlet	X		
1.8 Door closing force	X			3.3 Top-of-car operating device	X		
1.9 Power closing of doors or gates	X			3.4 Clearance, refuge space standard railing	X		
1.10 Power opening of doors or gates	X			3.5 Normal terminal stopping devices	X		
1.11 Car vision panels & glass car doors	X			3.6 Final & emergency terminal stopping devices	X		
1.12 Car enclosure	X			3.7 Car leveling & anti-creep devices	X		
1.13 Emergency exit	X			3.8 Top emergency exit	X		
1.14 Ventilation	X			3.9 Floor & emergency identification numbering	X		
1.15 Signs & operating device symbols	X			3.10 Hoist-way construction	X		
1.16 Related load, platform area, & data plate	X			3.11 Hoist-way smoke control (IDPH only)	X		
1.17 Standby power operation	X			3.12 Pipes, wiring & ducts	X		
1.18 Restricted opening of car or hoist-way doors		X		3.13 Windows, projections, recesses, & setbacks	X		
1.19 Car ride	X			3.14 Hoist-way clearances	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.15 Multiple hoist-ways	X		
2.1 Access to Machine Space		X		3.16 Traveling cables & junction boxes	X		
2.2 Headroom	X			3.17 Door & gate equipment	X		
2.3 Lighting & receptacles		X		3.18 Car frame & stiles	X		
2.4 Machine space	X			3.19 Guide rails fastening & equipment	X		
2.5 Housekeeping	X			3.20 Governor rope	X		
2.6 Ventilation	X			3.21 Governor releasing carrier	X		
2.7 Fire extinguisher	X			3.22 Wire rope fastening & hitch plate	X		
2.8 Pipes, wiring, & ducts	X			3.23 Suspension rope	X		
2.9 Guarding of exposed auxiliary equipment	X			3.27 Crosshead data plate & rope data tags	X		
2.10 Numbering of elevators, machines, disconnects	X			3.28 Counterweight & counterweight bu er	X		
2.11 Disconnecting means & control		X		3.29 Counterweight safeties	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.30 (H) Speed test	X		
2.13 Governor, over-speed switch, & seal	X			3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.14 Code data plate	X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.30 (H) Hydraulic power unit	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A
2.31 (H) Relief valves	X			4.1 Car platform guard	X		
2.32 (H) Control valve	X			4.2 Hoist-way doors	X		
2.33 (H) Tanks	X			4.3 Vision panels	X		
2.34 (H) Flexible hydraulic hose & fitting assemblies	X			4.4 Hoistway door locking devices	X		
2.35 (H) Supply line & shutoff valve	X			4.5 Access to hoist -way	X		
2.36 (H) Hydraulic cylinders	X			4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS006114	Report Number: 4649749
------------------------------------	-------------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
1.18	X	Door restriction required
2.1		Machine room door is required to be self-locking
2.3		PROVIDE GJARD ON LIGHTS
2.11		Label disconnect with use and fed from data
5.1		PROVIDE NON COMBUSTIBLE SUMP HOLE COVER

Building Owner Information:

Owner Name:	DEPARTMENT OF FINANCE - 620 BLDG
Owner Address:	501 N. WEST ST., SUITE 2002
City, State, Zip:	JACKSON, MS 39201
Contact:	DEPARTMENT OF FINANCE - 620 BLDG
Signature:	 

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Hydraulic - Elevator or Dumbwaiter**

Date of Inspection: 07/17/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649745

Building Location and Unit Information

Building Name:	DFA 700 BUILDING	MS Unit ID Number:	MS006115	Unit Designation:	1
Address:	700 NORTH STATE	Manufacturer:	Dover	Installed Year:	1995
City, State, Zip:	JACKSON MS 39201	Speed:	125 fpm	Capacity:	3500 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	5
				Openings:	5

(Continuation)

MS Unit ID Number: MS006115	Report Number: 4649745
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1 Door reopening device	X			2.38 (H) Roped water hydraulic elevators	X		
1.2 Stop switches	X			2.39 (H) Low oil protection	X		
1.3 Operating control devices	X			2.40 Maintenance records		X	
1.4 Sills & car floor	X			2.41 Static control	X		
1.5 Car lighting & receptacles	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.6 Car emergency signal-lighting	X			3.1 Top-of-car stop switch	X		
1.7 Car door or gate	X			3.2 Car top light & outlet	X		
1.8 Door closing force	X			3.3 Top-of-car operating device	X		
1.9 Power closing of doors or gates	X			3.4 Clearance, refuge space standard railing		X	
1.10 Power opening of doors or gates	X			3.5 Normal terminal stopping devices	X		
1.11 Car vision panels & glass car doors	X			3.6 Final & emergency terminal stopping devices	X		
1.12 Car enclosure		X		3.7 Car leveling & anti-creep devices	X		
1.13 Emergency exit	X			3.8 Top emergency exit	X		
1.14 Ventilation	X			3.9 Floor & emergency identification numbering	X		
1.15 Signs & operating device symbols	X			3.10 Hoist-way construction	X		
1.16 Related load, platform area, & data plate	X			3.11 Hoist-way smoke control (IDPH only)	X		
1.17 Standby power operation	X			3.12 Pipes, wiring & ducts	X		
1.18 Restricted opening of car or hoist-way doors		X		3.13 Windows, projections, recesses, & setbacks	X		
1.19 Car ride	X			3.14 Hoist-way clearances	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.15 Multiple hoist-ways	X		
2.1 Access to Machine Space		X		3.16 Traveling cables & junction boxes	X		
2.2 Headroom	X			3.17 Door & gate equipment	X		
2.3 Lighting & receptacles	X			3.18 Car frame & stiles	X		
2.4 Machine space	X			3.19 Guide rails fastening & equipment	X		
2.5 Housekeeping	X			3.20 Governor rope	X		
2.6 Ventilation	X			3.21 Governor releasing carrier	X		
2.7 Fire extinguisher	X			3.22 Wire rope fastening & hitch plate	X		
2.8 Pipes, wiring, & ducts	X			3.23 Suspension rope	X		
2.9 Guarding of exposed auxiliary equipment	X			3.27 Crosshead data plate & rope data tags	X		
2.10 Numbering of elevators, machines, disconnects	X			3.28 Counterweight & counterweight bu er	X		
2.11 Disconnecting means & control		X		3.29 Counterweight safeties	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.30 (H) Speed test	X		
2.13 Governor, over-speed switch, & seal	X			3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.14 Code data plate	X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.30 (H) Hydraulic power unit	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A
2.31 (H) Relief valves	X			4.1 Car platform guard	X		
2.32 (H) Control valve	X			4.2 Hoist-way doors	X		
2.33 (H) Tanks	X			4.3 Vision panels	X		
2.34 (H) Flexible hydraulic hose & fitting assemblies	X			4.4 Hoistway door locking devices	X		
2.35 (H) Supply line & shutoff valve	X			4.5 Access to hoist -way	X		
2.36 (H) Hydraulic cylinders	X			4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS006115	Report Number: 4649745
------------------------------------	-------------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation		X	
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
1.12		REPAIR SOFT SPOT IN CAB FLOOR
1.18	X	Door restriction required
2.1		Machine room door is required to be self-locking
2.1		machine room door is required to be self-closing
2.11		Provide a car light disconnect
2.11		Label disconnect with use and fed from data
2.40		Provide/maintain Firefighters' service monthly check log
3.4		Provide standard railing on the car-top that meets the code
5.1	X	Repair/provide pit ladder
5.1		PROVIDE NON COMBUSTIBLE SUMP HOLE COVER
6.1		CONNECT BUILDING FIRE SERVICE TO ELEVATOR

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	700 N
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEY

Commissioner of Insurance
State Fire Marshal

MARK HAIRE

Deputy Commissioner of Insurance



MAILING ADDRESS:

P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474

MISSISSIPPI INSURANCE DEPARTMENT

ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201

Periodic - Hydraulic - Elevator or Dumbwaiter

Date of Inspection: 07/17/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649746

Building Location and Unit Information

Building Name:	DFA 700 BUILDING	MS Unit ID Number:	MS006116	Unit Designation:	2
Address:	700 NORTH STATE	Manufacturer:	Dover	Installed Year:	1995
City, State, Zip:	JACKSON MS 39201	Speed:	125 fpm	Capacity:	3500 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	5
				Openings:	5

(Continuation)

MS Unit ID Number: MS006116	Report Number: 4649746
------------------------------------	-------------------------------



1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1 Door reopening device	X			2.38 (H) Roped water hydraulic elevators	X		
1.2 Stop switches	X			2.39 (H) Low oil protection	X		
1.3 Operating control devices	X			2.40 Maintenance records		X	
1.4 Sills & car floor	X			2.41 Static control	X		
1.5 Car lighting & receptacles	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.6 Car emergency signal-lighting	X			3.1 Top-of-car stop switch	X		
1.7 Car door or gate	X			3.2 Car top light & outlet	X		
1.8 Door closing force	X			3.3 Top-of-car operating device	X		
1.9 Power closing of doors or gates	X			3.4 Clearance, refuge space standard railing		X	
1.10 Power opening of doors or gates	X			3.5 Normal terminal stopping devices	X		
1.11 Car vision panels & glass car doors	X			3.6 Final & emergency terminal stopping devices	X		
1.12 Car enclosure	X			3.7 Car leveling & anti-creep devices	X		
1.13 Emergency exit	X			3.8 Top emergency exit	X		
1.14 Ventilation	X			3.9 Floor & emergency identification numbering	X		
1.15 Signs & operating device symbols	X			3.10 Hoist-way construction	X		
1.16 Related load, platform area, & data plate	X			3.11 Hoist-way smoke control (IDPH only)	X		
1.17 Standby power operation	X			3.12 Pipes, wiring & ducts	X		
1.18 Restricted opening of car or hoist-way doors	X			3.13 Windows, projections, recesses, & setbacks	X		
1.19 Car ride	X			3.14 Hoist-way clearances	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.15 Multiple hoist-ways	X		
2.1 Access to Machine Space	X			3.16 Traveling cables & junction boxes	X		
2.2 Headroom	X			3.17 Door & gate equipment	X		
2.3 Lighting & receptacles	X			3.18 Car frame & stiles	X		
2.4 Machine space	X			3.19 Guide rails fastening & equipment	X		
2.5 Housekeeping	X			3.20 Governor rope	X		
2.6 Ventilation	X			3.21 Governor releasing carrier	X		
2.7 Fire extinguisher	X			3.22 Wire rope fastening & hitch plate	X		
2.8 Pipes, wiring, & ducts	X			3.23 Suspension rope	X		
2.9 Guarding of exposed auxiliary equipment	X			3.27 Crosshead data plate & rope data tags	X		
2.10 Numbering of elevators, machines, disconnects	X			3.28 Counterweight & counterweight bu er	X		
2.11 Disconnecting means & control		X		3.29 Counterweight safeties	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.30 (H) Speed test	X		
2.13 Governor, over-speed switch, & seal	X			3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.14 Code data plate	X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.30 (H) Hydraulic power unit	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A
2.31 (H) Relief valves	X			4.1 Car platform guard	X		
2.32 (H) Control valve	X			4.2 Hoist-way doors	X		
2.33 (H) Tanks	X			4.3 Vision panels	X		
2.34 (H) Flexible hydraulic hose & fitting assemblies	X			4.4 Hoistway door locking devices	X		
2.35 (H) Supply line & shutoff valve	X			4.5 Access to hoist -way	X		
2.36 (H) Hydraulic cylinders	X			4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS006116	Report Number: 4649746
------------------------------------	-------------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation		X	
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
2.11		Provide a car light disconnect
2.11		Label disconnect with use and fed from data
2.40		Provide/maintain Firefighters' service monthly check log
3.4		Provide standard railing on the car-top that meets the code
5.1	X	Repair/provide pit ladder
6.1		CONNECT BUILDING FIRE SERVICE TO ELEVATOR

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	700 N
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	 

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Hydraulic - Elevator or Dumbwaiter**

Date of Inspection: 12/07/2022		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 3914029

Building Location and Unit Information

Building Name:	DFA BOLTON STATE OFFICE BUILDING	MS Unit ID Number:	MS010722	Unit Designation:	1
Address:	1141 BAYVIEW AVENUE	Manufacturer:	MCE	Installed Year:	1996
City, State, Zip:	BILOXI MS 39530	Speed:	200 fpm	Capacity:	4000 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	6
				Openings:	7

(Continuation)

MS Unit ID Number: MS010722	Report Number: 3914029
------------------------------------	-------------------------------



1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1 Door reopening device	X			2.38 (H) Roped water hydraulic elevators	X		
1.2 Stop switches	X			2.39 (H) Low oil protection	X		
1.3 Operating control devices	X			2.40 Maintenance records	X		
1.4 Sills & car floor	X			2.41 Static control	X		
1.5 Car lighting & receptacles	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.6 Car emergency signal-lighting	X			3.1 Top-of-car stop switch	X		
1.7 Car door or gate	X			3.2 Car top light & outlet	X		
1.8 Door closing force	X			3.3 Top-of-car operating device	X		
1.9 Power closing of doors or gates	X			3.4 Clearance, refuge space standard railing	X		
1.10 Power opening of doors or gates	X			3.5 Normal terminal stopping devices	X		
1.11 Car vision panels & glass car doors	X			3.6 Final & emergency terminal stopping devices	X		
1.12 Car enclosure	X			3.7 Car leveling & anti-creep devices	X		
1.13 Emergency exit	X			3.8 Top emergency exit	X		
1.14 Ventilation	X			3.9 Floor & emergency identification numbering	X		
1.15 Signs & operating device symbols	X			3.10 Hoist-way construction	X		
1.16 Related load, platform area, & data plate	X			3.11 Hoist-way smoke control (IDPH only)	X		
1.17 Standby power operation	X			3.12 Pipes, wiring & ducts	X		
1.18 Restricted opening of car or hoist-way doors	X			3.13 Windows, projections, recesses, & setbacks	X		
1.19 Car ride	X			3.14 Hoist-way clearances	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.15 Multiple hoist-ways	X		
2.1 Access to Machine Space	X			3.16 Traveling cables & junction boxes	X		
2.2 Headroom	X			3.17 Door & gate equipment	X		
2.3 Lighting & receptacles	X			3.18 Car frame & stiles	X		
2.4 Machine space	X			3.19 Guide rails fastening & equipment	X		
2.5 Housekeeping	X			3.20 Governor rope	X		
2.6 Ventilation	X			3.21 Governor releasing carrier	X		
2.7 Fire extinguisher	X			3.22 Wire rope fastening & hitch plate	X		
2.8 Pipes, wiring, & ducts	X			3.23 Suspension rope	X		
2.9 Guarding of exposed auxiliary equipment	X			3.27 Crosshead data plate & rope data tags	X		
2.10 Numbering of elevators, machines, disconnects	X			3.28 Counterweight & counterweight bu er	X		
2.11 Disconnecting means & control	X			3.29 Counterweight safeties	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.30 (H) Speed test	X		
2.13 Governor, over-speed switch, & seal		X		3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.14 Code data plate	X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.30 (H) Hydraulic power unit	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A
2.31 (H) Relief valves	X			4.1 Car platform guard	X		
2.32 (H) Control valve	X			4.2 Hoist-way doors	X		
2.33 (H) Tanks	X			4.3 Vision panels	X		
2.34 (H) Flexible hydraulic hose & fitting assemblies	X			4.4 Hoistway door locking devices	X		
2.35 (H) Supply line & shutoff valve	X			4.5 Access to hoist -way	X		
2.36 (H) Hydraulic cylinders	X			4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS010722	Report Number: 3914029
------------------------------------	-------------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
2.13		PERFORM ANNUAL TEST

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	501 N WEST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	 

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Traction - Elevator / Dumbwaiter**

Date of Inspection: 12/07/2022		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 3914030

Building Location and Unit Information

Building Name:	DFA BOLTON STATE OFFICE BUILDING	MS Unit ID Number:	MS010723	Unit Designation:	2
Address:	1141 BAYVIEW AVENUE	Manufacturer:	MCE	Installed Year:	1996
City, State, Zip:	BILOXI MS 39530	Speed:	200 fpm	Capacity:	4000 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	6
				Openings:	7

(Continuation)

MS Unit ID Number: MS010723	Report Number: 3914030
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device	X			2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting	X			2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records	X		
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing	X		
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors	X			3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space	X			3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles	X			3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control	X			3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal		X		3.23 Suspension rope	X		
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & deflector sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A

MS Unit ID Number: MS010723	Report Number: 3914030
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
2.13		PERFORM ANNUAL TEST

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	501 N WEST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Traction - Elevator / Dumbwaiter**

Date of Inspection: 12/07/2022		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 3914032

Building Location and Unit Information

Building Name:	DFA BOLTON STATE OFFICE BUILDING	MS Unit ID Number:	MS010724	Unit Designation:	3
Address:	1141 BAYVIEW AVENUE	Manufacturer:	MCE	Installed Year:	2020
City, State, Zip:	BILOXI MS 39530	Speed:	200 fpm	Capacity:	4000 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	6
				Openings:	7

(Continuation)

MS Unit ID Number: MS010724	Report Number: 3914032
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device	X			2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting	X			2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records	X		
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing	X		
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors	X			3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space	X			3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles	X			3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control	X			3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal		X		3.23 Suspension rope	X		
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & deflector sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A

MS Unit ID Number: MS010724	Report Number: 3914032
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
2.13		PERFORM ANNUAL TEST

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	501 N WEST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Traction - Elevator / Dumbwaiter**

Date of Inspection: 07/18/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649795

Building Location and Unit Information

Building Name:	DFA CAPERS BUILDING ARCHIEVES & HISTORY	MS Unit ID Number:	MS006105	Unit Designation:	FRONT
Address:	100 STATE	Manufacturer:	Other	Installed Year:	1998
City, State, Zip:	JACKSON MS 39201	Speed:	150 fpm	Capacity:	2000 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	4
				Openings:	4

(Continuation)

MS Unit ID Number: MS006105	Report Number: 4649795
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device		X		2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches		X		2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting		X		2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records	X		
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing		X	
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors		X		3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space	X			3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles	X			3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control		X		3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23 Suspension rope	X		
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & deflector sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A

MS Unit ID Number: MS006105	Report Number: 4649795
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
1.1		Photoelectric Device(s) Inoperable
1.2	X	Emergency stop switch alarm required
1.6		PROVIDE ADA TELEPHONE
1.18	X	Door restriction required
2.11		Provide a car light disconnect
2.11		Label disconnect with use and fed from data
3.4		Provide standard railing on the car-top that meets the code
5.1	X	Repair/provide pit ladder
5.1		PROVIDE PIT LIGHTING

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	100 STATE
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Traction - Elevator / Dumbwaiter**

Date of Inspection: 07/18/2023	Conveyance Type: Passenger Elevator		
Inspection Type: <input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649790	

Building Location and Unit Information

Building Name:	DFA CAPERS BUILDING ARCHIEVES & HISTORY	MS Unit ID Number:	MS006104	Unit Designation:	BACK
Address:	100 STATE	Manufacturer:	Other	Installed Year:	1998
City, State, Zip:	JACKSON MS 39201	Speed:	150 fpm	Capacity:	2000 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	5
				Openings:	5

(Continuation)

MS Unit ID Number: MS006104	Report Number: 4649790
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device		X		2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting		X		2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records	X		
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing		X	
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors		X		3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space	X			3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles	X			3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control		X		3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23 Suspension rope		X	
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & de ctor sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A

MS Unit ID Number: MS006104	Report Number: 4649790
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
1.1		Photoelectric Device(s) Inoperable
1.6		LPROVIDE ADA TELEPHONE
1.18	X	Door restriction required
2.11		Provide a car light disconnect
2.11		Label disconnect with use and fed from data
3.4		Provide standard railing on the car-top that meets the code
3.23	X	Replace suspension ropes due to reduced diameter
5.1	X	Repair/provide pit ladder
5.1		PROVIDE PIT LIGHTING

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	100 STATE
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Hydraulic - Elevator or Dumbwaiter**

Date of Inspection: 07/18/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649811

Building Location and Unit Information

Building Name:	DFA CENTRAL HIGH SCHOOL	MS Unit ID Number:	MS006096	Unit Designation:	1
Address:	359 WEST STREET	Manufacturer:	Schindler	Installed Year:	2008
City, State, Zip:	JACKSON MS 39201	Speed:	150 fpm	Capacity:	3500 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	3
				Openings:	3

(Continuation)

MS Unit ID Number: MS006096	Report Number: 4649811
------------------------------------	-------------------------------



1. ELEVATOR INSIDE OF CAR				Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1	Door reopening device			X			2.38 (H) Roped water hydraulic elevators	X		
1.2	Stop switches			X			2.39 (H) Low oil protection	X		
1.3	Operating control devices			X			2.40 Maintenance records	X		
1.4	Sills & car floor			X			2.41 Static control	X		
1.5	Car lighting & receptacles			X			3. ELEVATOR TOP OF CAR			
1.6	Car emergency signal-lighting			X			3.1 Top-of-car stop switch	X		
1.7	Car door or gate			X			3.2 Car top light & outlet	X		
1.8	Door closing force			X			3.3 Top-of-car operating device	X		
1.9	Power closing of doors or gates			X			3.4 Clearance, refuge space standard railing	X		
1.10	Power opening of doors or gates			X			3.5 Normal terminal stopping devices	X		
1.11	Car vision panels & glass car doors			X			3.6 Final & emergency terminal stopping devices	X		
1.12	Car enclosure			X			3.7 Car leveling & anti-creep devices	X		
1.13	Emergency exit			X			3.8 Top emergency exit	X		
1.14	Ventilation			X			3.9 Floor & emergency identification numbering	X		
1.15	Signs & operating device symbols			X			3.10 Hoist-way construction	X		
1.16	Related load, platform area, & data plate			X			3.11 Hoist-way smoke control (IDPH only)	X		
1.17	Standby power operation			X			3.12 Pipes, wiring & ducts	X		
1.18	Restricted opening of car or hoist-way doors				X		3.13 Windows, projections, recesses, & setbacks	X		
1.19	Car ride			X			3.14 Hoist-way clearances	X		
2. ELEVATOR MACHINE ROOM				Pass	Fail	N/A	3.15 Multiple hoist-ways	X		
2.1	Access to Machine Space			X			3.16 Traveling cables & junction boxes	X		
2.2	Headroom			X			3.17 Door & gate equipment	X		
2.3	Lighting & receptacles			X			3.18 Car frame & stiles	X		
2.4	Machine space			X			3.19 Guide rails fastening & equipment	X		
2.5	Housekeeping			X			3.20 Governor rope	X		
2.6	Ventilation			X			3.21 Governor releasing carrier	X		
2.7	Fire extinguisher			X			3.22 Wire rope fastening & hitch plate	X		
2.8	Pipes, wiring, & ducts			X			3.23 Suspension rope	X		
2.9	Guarding of exposed auxiliary equipment			X			3.27 Crosshead data plate & rope data tags	X		
2.10	Numbering of elevators, machines, disconnects			X			3.28 Counterweight & counterweight bu er	X		
2.11	Disconnecting means & control			X			3.29 Counterweight safeties	X		
2.12	Controller wiring, fuses, grounding, etc.			X			3.30 (H) Speed test	X		
2.13	Governor, over-speed switch, & seal			X			3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.14	Code data plate			X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.30 (H)	Hydraulic power unit			X			4. ELEVATOR OUTSIDE HOIST-WAY			
2.31 (H)	Relief valves				X		4.1 Car platform guard	X		
2.32 (H)	Control valve			X			4.2 Hoist-way doors	X		
2.33 (H)	Tanks			X			4.3 Vision panels	X		
2.34 (H)	Flexible hydraulic hose & fitting assemblies			X			4.4 Hoistway door locking devices	X		
2.35 (H)	Supply line & shutoff valve			X			4.5 Access to hoist -way	X		
2.36 (H)	Hydraulic cylinders			X			4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS006096	Report Number: 4649811
------------------------------------	-------------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
1.18	X	Door restriction required
2.31		PROVIDE RUPTURE VALVE
5.1	X	Pit stop switch is required to be reachable from the hoistway access point and adjacent to pit ladder
5.1		FILL IN VOID AROUND JACK ASSEMBLY

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	359 WEST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	 

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Hydraulic - Elevator or Dumbwaiter**

Date of Inspection: 07/18/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649812

Building Location and Unit Information

Building Name:	DFA CENTRAL HIGH SCHOOL	MS Unit ID Number:	MS006097	Unit Designation:	2
Address:	359 WEST STREET	Manufacturer:	Schindler	Installed Year:	2008
City, State, Zip:	JACKSON MS 39201	Speed:	150 fpm	Capacity:	3500 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	3
				Openings:	3

(Continuation)

MS Unit ID Number: MS006097	Report Number: 4649812
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1 Door reopening device	X			2.38 (H) Roped water hydraulic elevators	X		
1.2 Stop switches	X			2.39 (H) Low oil protection	X		
1.3 Operating control devices	X			2.40 Maintenance records	X		
1.4 Sills & car floor	X			2.41 Static control	X		
1.5 Car lighting & receptacles	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.6 Car emergency signal-lighting	X			3.1 Top-of-car stop switch	X		
1.7 Car door or gate	X			3.2 Car top light & outlet	X		
1.8 Door closing force	X			3.3 Top-of-car operating device	X		
1.9 Power closing of doors or gates	X			3.4 Clearance, refuge space standard railing	X		
1.10 Power opening of doors or gates	X			3.5 Normal terminal stopping devices	X		
1.11 Car vision panels & glass car doors	X			3.6 Final & emergency terminal stopping devices	X		
1.12 Car enclosure	X			3.7 Car leveling & anti-creep devices	X		
1.13 Emergency exit	X			3.8 Top emergency exit	X		
1.14 Ventilation	X			3.9 Floor & emergency identification numbering	X		
1.15 Signs & operating device symbols	X			3.10 Hoist-way construction	X		
1.16 Related load, platform area, & data plate	X			3.11 Hoist-way smoke control (IDPH only)	X		
1.17 Standby power operation	X			3.12 Pipes, wiring & ducts	X		
1.18 Restricted opening of car or hoist-way doors		X		3.13 Windows, projections, recesses, & setbacks	X		
1.19 Car ride	X			3.14 Hoist-way clearances	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.15 Multiple hoist-ways	X		
2.1 Access to Machine Space	X			3.16 Traveling cables & junction boxes	X		
2.2 Headroom	X			3.17 Door & gate equipment	X		
2.3 Lighting & receptacles	X			3.18 Car frame & stiles	X		
2.4 Machine space	X			3.19 Guide rails fastening & equipment	X		
2.5 Housekeeping	X			3.20 Governor rope	X		
2.6 Ventilation	X			3.21 Governor releasing carrier	X		
2.7 Fire extinguisher	X			3.22 Wire rope fastening & hitch plate	X		
2.8 Pipes, wiring, & ducts	X			3.23 Suspension rope	X		
2.9 Guarding of exposed auxiliary equipment	X			3.27 Crosshead data plate & rope data tags	X		
2.10 Numbering of elevators, machines, disconnects	X			3.28 Counterweight & counterweight bu er	X		
2.11 Disconnecting means & control	X			3.29 Counterweight safeties	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.30 (H) Speed test	X		
2.13 Governor, over-speed switch, & seal	X			3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.14 Code data plate	X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.30 (H) Hydraulic power unit	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A
2.31 (H) Relief valves		X		4.1 Car platform guard	X		
2.32 (H) Control valve	X			4.2 Hoist-way doors	X		
2.33 (H) Tanks	X			4.3 Vision panels	X		
2.34 (H) Flexible hydraulic hose & fitting assemblies	X			4.4 Hoistway door locking devices	X		
2.35 (H) Supply line & shutoff valve	X			4.5 Access to hoist -way	X		
2.36 (H) Hydraulic cylinders	X			4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS006097	Report Number: 4649812
------------------------------------	-------------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
2.31		PROVIDE RUPTURE VALVE
5.1	X	Pit stop switch is required to be reachable from the hoistway access point and adjacent to pit ladder
5.1		FILL IN VOID AROUND JACK ASSEMBLY

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	359 WEST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Hydraulic - Elevator or Dumbwaiter**

Date of Inspection: 07/18/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649813

Building Location and Unit Information

Building Name:	DFA CENTRAL HIGH SCHOOL	MS Unit ID Number:	MS006098	Unit Designation:	3
Address:	359 WEST STREET	Manufacturer:	Schindler	Installed Year:	2008
City, State, Zip:	JACKSON MS 39201	Speed:	150 fpm	Capacity:	2100 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	3
				Openings:	3

(Continuation)

MS Unit ID Number: MS006098	Report Number: 4649813
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1 Door reopening device	X			2.38 (H) Roped water hydraulic elevators	X		
1.2 Stop switches	X			2.39 (H) Low oil protection	X		
1.3 Operating control devices	X			2.40 Maintenance records	X		
1.4 Sills & car floor	X			2.41 Static control	X		
1.5 Car lighting & receptacles	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.6 Car emergency signal-lighting	X			3.1 Top-of-car stop switch	X		
1.7 Car door or gate	X			3.2 Car top light & outlet	X		
1.8 Door closing force	X			3.3 Top-of-car operating device	X		
1.9 Power closing of doors or gates	X			3.4 Clearance, refuge space standard railing	X		
1.10 Power opening of doors or gates	X			3.5 Normal terminal stopping devices	X		
1.11 Car vision panels & glass car doors	X			3.6 Final & emergency terminal stopping devices	X		
1.12 Car enclosure	X			3.7 Car leveling & anti-creep devices	X		
1.13 Emergency exit	X			3.8 Top emergency exit	X		
1.14 Ventilation	X			3.9 Floor & emergency identification numbering	X		
1.15 Signs & operating device symbols	X			3.10 Hoist-way construction	X		
1.16 Related load, platform area, & data plate	X			3.11 Hoist-way smoke control (IDPH only)	X		
1.17 Standby power operation	X			3.12 Pipes, wiring & ducts	X		
1.18 Restricted opening of car or hoist-way doors		X		3.13 Windows, projections, recesses, & setbacks	X		
1.19 Car ride	X			3.14 Hoist-way clearances	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.15 Multiple hoist-ways	X		
2.1 Access to Machine Space	X			3.16 Traveling cables & junction boxes	X		
2.2 Headroom	X			3.17 Door & gate equipment	X		
2.3 Lighting & receptacles	X			3.18 Car frame & stiles	X		
2.4 Machine space	X			3.19 Guide rails fastening & equipment	X		
2.5 Housekeeping	X			3.20 Governor rope	X		
2.6 Ventilation	X			3.21 Governor releasing carrier	X		
2.7 Fire extinguisher	X			3.22 Wire rope fastening & hitch plate	X		
2.8 Pipes, wiring, & ducts	X			3.23 Suspension rope	X		
2.9 Guarding of exposed auxiliary equipment	X			3.27 Crosshead data plate & rope data tags	X		
2.10 Numbering of elevators, machines, disconnects	X			3.28 Counterweight & counterweight bu er	X		
2.11 Disconnecting means & control		X		3.29 Counterweight safeties	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.30 (H) Speed test	X		
2.13 Governor, over-speed switch, & seal	X			3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.14 Code data plate	X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.30 (H) Hydraulic power unit	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A
2.31 (H) Relief valves		X		4.1 Car platform guard	X		
2.32 (H) Control valve	X			4.2 Hoist-way doors	X		
2.33 (H) Tanks	X			4.3 Vision panels	X		
2.34 (H) Flexible hydraulic hose & fitting assemblies	X			4.4 Hoistway door locking devices	X		
2.35 (H) Supply line & shutoff valve	X			4.5 Access to hoist -way	X		
2.36 (H) Hydraulic cylinders	X			4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS006098	Report Number: 4649813
------------------------------------	-------------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
1.18	X	Door restriction required
2.11		Label disconnect with use and fed from data
2.31		PROVIDE RUPTURE VALVE

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	359 WEST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Hydraulic - Elevator or Dumbwaiter**

Date of Inspection: 07/18/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649814

Building Location and Unit Information

Building Name:	DFA CENTRAL HIGH SCHOOL	MS Unit ID Number:	MS006099	Unit Designation:	4
Address:	359 WEST STREET	Manufacturer:	Schindler	Installed Year:	2008
City, State, Zip:	JACKSON MS 39201	Speed:	150 fpm	Capacity:	3500 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	4
				Openings:	4

(Continuation)

MS Unit ID Number: MS006099	Report Number: 4649814
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1 Door reopening device	X			2.38 (H) Roped water hydraulic elevators	X		
1.2 Stop switches	X			2.39 (H) Low oil protection	X		
1.3 Operating control devices	X			2.40 Maintenance records	X		
1.4 Sills & car floor	X			2.41 Static control	X		
1.5 Car lighting & receptacles	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.6 Car emergency signal-lighting	X			3.1 Top-of-car stop switch	X		
1.7 Car door or gate	X			3.2 Car top light & outlet	X		
1.8 Door closing force	X			3.3 Top-of-car operating device	X		
1.9 Power closing of doors or gates	X			3.4 Clearance, refuge space standard railing	X		
1.10 Power opening of doors or gates	X			3.5 Normal terminal stopping devices	X		
1.11 Car vision panels & glass car doors	X			3.6 Final & emergency terminal stopping devices	X		
1.12 Car enclosure	X			3.7 Car leveling & anti-creep devices	X		
1.13 Emergency exit	X			3.8 Top emergency exit	X		
1.14 Ventilation	X			3.9 Floor & emergency identification numbering	X		
1.15 Signs & operating device symbols	X			3.10 Hoist-way construction	X		
1.16 Related load, platform area, & data plate	X			3.11 Hoist-way smoke control (IDPH only)	X		
1.17 Standby power operation	X			3.12 Pipes, wiring & ducts	X		
1.18 Restricted opening of car or hoist-way doors		X		3.13 Windows, projections, recesses, & setbacks	X		
1.19 Car ride	X			3.14 Hoist-way clearances	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.15 Multiple hoist-ways	X		
2.1 Access to Machine Space	X			3.16 Traveling cables & junction boxes	X		
2.2 Headroom	X			3.17 Door & gate equipment	X		
2.3 Lighting & receptacles	X			3.18 Car frame & stiles	X		
2.4 Machine space	X			3.19 Guide rails fastening & equipment	X		
2.5 Housekeeping	X			3.20 Governor rope	X		
2.6 Ventilation	X			3.21 Governor releasing carrier	X		
2.7 Fire extinguisher	X			3.22 Wire rope fastening & hitch plate	X		
2.8 Pipes, wiring, & ducts	X			3.23 Suspension rope	X		
2.9 Guarding of exposed auxiliary equipment	X			3.27 Crosshead data plate & rope data tags	X		
2.10 Numbering of elevators, machines, disconnects	X			3.28 Counterweight & counterweight bu er	X		
2.11 Disconnecting means & control		X		3.29 Counterweight safeties	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.30 (H) Speed test	X		
2.13 Governor, over-speed switch, & seal	X			3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.14 Code data plate	X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.30 (H) Hydraulic power unit	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A
2.31 (H) Relief valves	X			4.1 Car platform guard	X		
2.32 (H) Control valve	X			4.2 Hoist-way doors	X		
2.33 (H) Tanks	X			4.3 Vision panels	X		
2.34 (H) Flexible hydraulic hose & fitting assemblies	X			4.4 Hoistway door locking devices	X		
2.35 (H) Supply line & shutoff valve	X			4.5 Access to hoist -way	X		
2.36 (H) Hydraulic cylinders	X			4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS006099	Report Number: 4649814
------------------------------------	-------------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
1.18	X	Door restriction required
2.11		Label disconnect with use and fed from data
5.1	X	Repair/provide pit ladder
5.1		PROVIDE NON COMBUSTIBLE SUMP HOLE COVER. FILL IN VOID AROUND JACK ASSEMBLY

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	359 WEST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Hydraulic - Elevator or Dumbwaiter**

Date of Inspection: 07/17/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649763

Building Location and Unit Information

Building Name:	DFA GARTIN JUSTICE BUILDING	MS Unit ID Number:	MS006142	Unit Designation:	1 WEST
Address:	450 HIGH STREET	Manufacturer:	ThyssenKrupp	Installed Year:	2006
City, State, Zip:	JACKSON MS 39201	Speed:	150 fpm	Capacity:	3500 lbs
Contact:	DEPARTMENT OF FINANCE & Phone: (769) 245-6329	Stops:	5	Openings:	5

(Continuation)

MS Unit ID Number: MS006142	Report Number: 4649763
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR				Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1	Door reopening device			X			2.38 (H) Roped water hydraulic elevators	X		
1.2	Stop switches			X			2.39 (H) Low oil protection	X		
1.3	Operating control devices			X			2.40 Maintenance records	X		
1.4	Sills & car floor			X			2.41 Static control	X		
1.5	Car lighting & receptacles			X			3. ELEVATOR TOP OF CAR			
1.6	Car emergency signal-lighting			X			3.1 Top-of-car stop switch	X		
1.7	Car door or gate			X			3.2 Car top light & outlet	X		
1.8	Door closing force			X			3.3 Top-of-car operating device	X		
1.9	Power closing of doors or gates			X			3.4 Clearance, refuge space standard railing	X		
1.10	Power opening of doors or gates			X			3.5 Normal terminal stopping devices	X		
1.11	Car vision panels & glass car doors			X			3.6 Final & emergency terminal stopping devices	X		
1.12	Car enclosure			X			3.7 Car leveling & anti-creep devices	X		
1.13	Emergency exit			X			3.8 Top emergency exit	X		
1.14	Ventilation			X			3.9 Floor & emergency identification numbering	X		
1.15	Signs & operating device symbols			X			3.10 Hoist-way construction	X		
1.16	Related load, platform area, & data plate			X			3.11 Hoist-way smoke control (IDPH only)	X		
1.17	Standby power operation			X			3.12 Pipes, wiring & ducts	X		
1.18	Restricted opening of car or hoist-way doors			X			3.13 Windows, projections, recesses, & setbacks	X		
1.19	Car ride			X			3.14 Hoist-way clearances	X		
2. ELEVATOR MACHINE ROOM				Pass	Fail	N/A	3.15 Multiple hoist-ways	X		
2.1	Access to Machine Space				X		3.16 Traveling cables & junction boxes	X		
2.2	Headroom			X			3.17 Door & gate equipment	X		
2.3	Lighting & receptacles				X		3.18 Car frame & stiles	X		
2.4	Machine space			X			3.19 Guide rails fastening & equipment	X		
2.5	Housekeeping			X			3.20 Governor rope	X		
2.6	Ventilation			X			3.21 Governor releasing carrier	X		
2.7	Fire extinguisher			X			3.22 Wire rope fastening & hitch plate	X		
2.8	Pipes, wiring, & ducts			X			3.23 Suspension rope	X		
2.9	Guarding of exposed auxiliary equipment			X			3.27 Crosshead data plate & rope data tags	X		
2.10	Numbering of elevators, machines, disconnects			X			3.28 Counterweight & counterweight bu er	X		
2.11	Disconnecting means & control				X		3.29 Counterweight safeties	X		
2.12	Controller wiring, fuses, grounding, etc.			X			3.30 (H) Speed test	X		
2.13	Governor, over-speed switch, & seal			X			3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.14	Code data plate			X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.30	(H) Hydraulic power unit			X			4. ELEVATOR OUTSIDE HOIST-WAY			
2.31	(H) Relief valves			X			4.1 Car platform guard	X		
2.32	(H) Control valve			X			4.2 Hoist-way doors	X		
2.33	(H) Tanks			X			4.3 Vision panels	X		
2.34	(H) Flexible hydraulic hose & fitting assemblies			X			4.4 Hoistway door locking devices	X		
2.35	(H) Supply line & shutoff valve				X		4.5 Access to hoist -way	X		
2.36	(H) Hydraulic cylinders			X			4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS006142	Report Number: 4649763
------------------------------------	-------------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
2.1		Machine room door is required to be self-locking
2.3		PROVIDE GUARD ON LIGHTING
2.11		Label disconnect with use and fed from data
2.35		Shutoff valve required in machine room

Building Owner Information:

Owner Name:	DEPARTMENT OF FINANCE & ADMINISTRATION
Owner Address:	501 N. WEST ST., SUITE 2002
City, State, Zip:	JACKSON, MS 39201
Contact:	DEPARTMENT OF FINANCE & ADMINISTRATION
Signature:	

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Hydraulic - Elevator or Dumbwaiter**

Date of Inspection: 07/17/2023	Conveyance Type: Passenger Elevator		
Inspection Type: <input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649767	

Building Location and Unit Information

Building Name: DFA GARTIN JUSTICE BUILDING	MS Unit ID Number: MS006143	Unit Designation: 2
Address: 450 HIGH STREET	Manufacturer: ThyssenKrupp	Installed Year: 2006
City, State, Zip: JACKSON MS 39201	Speed: 150 fpm	Capacity: 3500 lbs
Contact: DEPARTMENT OF FINANCE & Phone: (769) 245-6329	Stops: 5	Openings: 5

(Continuation)

MS Unit ID Number: MS006143	Report Number: 4649767
-----------------------------	------------------------



1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1 Door reopening device	X			2.38 (H) Roped water hydraulic elevators	X		
1.2 Stop switches	X			2.39 (H) Low oil protection	X		
1.3 Operating control devices	X			2.40 Maintenance records		X	
1.4 Sills & car floor	X			2.41 Static control	X		
1.5 Car lighting & receptacles	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.6 Car emergency signal-lighting		X		3.1 Top-of-car stop switch	X		
1.7 Car door or gate	X			3.2 Car top light & outlet	X		
1.8 Door closing force	X			3.3 Top-of-car operating device	X		
1.9 Power closing of doors or gates	X			3.4 Clearance, refuge space standard railing	X		
1.10 Power opening of doors or gates	X			3.5 Normal terminal stopping devices	X		
1.11 Car vision panels & glass car doors	X			3.6 Final & emergency terminal stopping devices	X		
1.12 Car enclosure	X			3.7 Car leveling & anti-creep devices	X		
1.13 Emergency exit	X			3.8 Top emergency exit	X		
1.14 Ventilation	X			3.9 Floor & emergency identification numbering	X		
1.15 Signs & operating device symbols	X			3.10 Hoist-way construction	X		
1.16 Related load, platform area, & data plate	X			3.11 Hoist-way smoke control (IDPH only)	X		
1.17 Standby power operation	X			3.12 Pipes, wiring & ducts	X		
1.18 Restricted opening of car or hoist-way doors	X			3.13 Windows, projections, recesses, & setbacks	X		
1.19 Car ride	X			3.14 Hoist-way clearances	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.15 Multiple hoist-ways	X		
2.1 Access to Machine Space		X		3.16 Traveling cables & junction boxes	X		
2.2 Headroom	X			3.17 Door & gate equipment	X		
2.3 Lighting & receptacles		X		3.18 Car frame & stiles	X		
2.4 Machine space	X			3.19 Guide rails fastening & equipment	X		
2.5 Housekeeping	X			3.20 Governor rope	X		
2.6 Ventilation	X			3.21 Governor releasing carrier	X		
2.7 Fire extinguisher	X			3.22 Wire rope fastening & hitch plate	X		
2.8 Pipes, wiring, & ducts	X			3.23 Suspension rope	X		
2.9 Guarding of exposed auxiliary equipment	X			3.27 Crosshead data plate & rope data tags	X		
2.10 Numbering of elevators, machines, disconnects	X			3.28 Counterweight & counterweight bu er	X		
2.11 Disconnecting means & control		X		3.29 Counterweight safeties	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.30 (H) Speed test	X		
2.13 Governor, over-speed switch, & seal	X			3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.14 Code data plate	X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.30 (H) Hydraulic power unit	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A
2.31 (H) Relief valves	X			4.1 Car platform guard	X		
2.32 (H) Control valve	X			4.2 Hoist-way doors	X		
2.33 (H) Tanks	X			4.3 Vision panels	X		
2.34 (H) Flexible hydraulic hose & fitting assemblies	X			4.4 Hoistway door locking devices	X		
2.35 (H) Supply line & shutoff valve	X			4.5 Access to hoist -way	X		
2.36 (H) Hydraulic cylinders	X			4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS006143	Report Number: 4649767
------------------------------------	-------------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
1.6	X	Emergency phone not working
2.1		Machine room door is required to be self-locking
2.3		PROVIDE GUARD ON LIGHTING
2.11		Label disconnect with use and fed from data
2.40		Provide/maintain Firefighters' service monthly check log

Building Owner Information:

Owner Name:	DEPARTMENT OF FINANCE & ADMINISTRATION
Owner Address:	501 N. WEST ST., SUITE 2002
City, State, Zip:	JACKSON, MS 39201
Contact:	DEPARTMENT OF FINANCE & ADMINISTRATION
Signature:	 

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Traction - Elevator / Dumbwaiter**

Date of Inspection: 07/17/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649769

Building Location and Unit Information

Building Name:	DFA GARTIN JUSTICE BUILDING	MS Unit ID Number:	MS006144	Unit Designation:	3
Address:	450 HIGH STREET	Manufacturer:	ThyssenKrupp	Installed Year:	2006
City, State, Zip:	JACKSON MS 39201	Speed:	350 fpm	Capacity:	5000 lbs
Contact:	DEPARTMENT OF FINANCE & Phone: (769) 245-6329	Stops:	5	Openings:	5

(Continuation)

MS Unit ID Number: MS006144	Report Number: 4649769
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device	X			2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting		X		2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records		X	
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing	X		
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors	X			3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space		X		3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles		X		3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control		X		3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23 Suspension rope	X		
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & de ctor sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A

MS Unit ID Number: MS006144	Report Number: 4649769
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
1.6	X	Emergency phone not working
2.1		Machine room door is required to be self-locking
2.1		machine room door is required to be self-closing
2.3		PROVIDE GUARDS ON LIGHTING
2.11		Label disconnect with use and fed from data
2.40		Provide/maintain Firefighters' service monthly check log

Building Owner Information:

Owner Name:	DEPARTMENT OF FINANCE & ADMINISTRATION
Owner Address:	501 N. WEST ST., SUITE 2002
City, State, Zip:	JACKSON, MS 39201
Contact:	DEPARTMENT OF FINANCE & ADMINISTRATION
Signature:	

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Traction - Elevator / Dumbwaiter**

Date of Inspection: 07/17/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649772

Building Location and Unit Information

Building Name:	DFA GARTIN JUSTICE BUILDING	MS Unit ID Number:	MS006145	Unit Designation:	4
Address:	450 HIGH STREET	Manufacturer:	ThyssenKrupp	Installed Year:	2006
City, State, Zip:	JACKSON MS 39201	Speed:	350 fpm	Capacity:	5000 lbs
Contact:	DEPARTMENT OF FINANCE & Phone: (769) 245-6329	Stops:	5	Openings:	5

(Continuation)

MS Unit ID Number: MS006145	Report Number: 4649772
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device	X			2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting	X			2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records		X	
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing		X	
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors	X			3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space		X		3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles		X		3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control		X		3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23 Suspension rope	X		
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & deflector sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A

MS Unit ID Number: MS006145	Report Number: 4649772
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
2.1		Machine room door is required to be self-locking
2.1		machine room door is required to be self-closing
2.3		PROVIDE GUARDS ON LIGHTING
2.11		Label disconnect with use and fed from data
2.40		Provide/maintain Firefighters' service monthly check log
3.4		Provide standard railing on the car-top that meets the code
5.1	X	Pit stop switch is required to be reachable from the hoistway access point and adjacent to pit ladder
5.1		Pit light switch is required to be reachable from the access point and adjacent to pit ladder

Building Owner Information:

Owner Name:	DEPARTMENT OF FINANCE & ADMINISTRATION
Owner Address:	501 N. WEST ST., SUITE 2002
City, State, Zip:	JACKSON, MS 39201
Contact:	DEPARTMENT OF FINANCE & ADMINISTRATION
Signature:	

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Hydraulic - Elevator or Dumbwaiter**

Date of Inspection: 07/17/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649753

Building Location and Unit Information

Building Name:	DFA GARTIN JUSTICE BUILDING	MS Unit ID Number:	MS006146	Unit Designation:	5
Address:	450 HIGH STREET	Manufacturer:	ThyssenKrupp	Installed Year:	2008
City, State, Zip:	JACKSON MS 39201	Speed:	150 fpm	Capacity:	3500 lbs
Contact:	DEPARTMENT OF FINANCE & Phone: (769) 245-6329	Stops:	3	Openings:	3

(Continuation)

MS Unit ID Number: MS006146	Report Number: 4649753
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR				Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1	Door reopening device			X			2.38 (H) Roped water hydraulic elevators	X		
1.2	Stop switches			X			2.39 (H) Low oil protection	X		
1.3	Operating control devices			X			2.40 Maintenance records		X	
1.4	Sills & car floor			X			2.41 Static control	X		
1.5	Car lighting & receptacles			X			3. ELEVATOR TOP OF CAR			
1.6	Car emergency signal-lighting			X			3.1 Top-of-car stop switch	X		
1.7	Car door or gate			X			3.2 Car top light & outlet	X		
1.8	Door closing force			X			3.3 Top-of-car operating device	X		
1.9	Power closing of doors or gates			X			3.4 Clearance, refuge space standard railing	X		
1.10	Power opening of doors or gates			X			3.5 Normal terminal stopping devices	X		
1.11	Car vision panels & glass car doors			X			3.6 Final & emergency terminal stopping devices	X		
1.12	Car enclosure			X			3.7 Car leveling & anti-creep devices	X		
1.13	Emergency exit			X			3.8 Top emergency exit	X		
1.14	Ventilation			X			3.9 Floor & emergency identification numbering	X		
1.15	Signs & operating device symbols			X			3.10 Hoist-way construction	X		
1.16	Related load, platform area, & data plate			X			3.11 Hoist-way smoke control (IDPH only)	X		
1.17	Standby power operation			X			3.12 Pipes, wiring & ducts	X		
1.18	Restricted opening of car or hoist-way doors			X			3.13 Windows, projections, recesses, & setbacks	X		
1.19	Car ride			X			3.14 Hoist-way clearances	X		
2. ELEVATOR MACHINE ROOM				Pass	Fail	N/A	3.15 Multiple hoist-ways	X		
2.1	Access to Machine Space			X			3.16 Traveling cables & junction boxes	X		
2.2	Headroom			X			3.17 Door & gate equipment	X		
2.3	Lighting & receptacles				X		3.18 Car frame & stiles	X		
2.4	Machine space			X			3.19 Guide rails fastening & equipment	X		
2.5	Housekeeping			X			3.20 Governor rope	X		
2.6	Ventilation			X			3.21 Governor releasing carrier	X		
2.7	Fire extinguisher			X			3.22 Wire rope fastening & hitch plate	X		
2.8	Pipes, wiring, & ducts			X			3.23 Suspension rope	X		
2.9	Guarding of exposed auxiliary equipment			X			3.27 Crosshead data plate & rope data tags	X		
2.10	Numbering of elevators, machines, disconnects			X			3.28 Counterweight & counterweight bu er	X		
2.11	Disconnecting means & control				X		3.29 Counterweight safeties	X		
2.12	Controller wiring, fuses, grounding, etc.			X			3.30 (H) Speed test	X		
2.13	Governor, over-speed switch, & seal			X			3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.14	Code data plate			X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.30	(H) Hydraulic power unit			X			4. ELEVATOR OUTSIDE HOIST-WAY			
2.31	(H) Relief valves			X			4.1 Car platform guard	X		
2.32	(H) Control valve			X			4.2 Hoist-way doors	X		
2.33	(H) Tanks			X			4.3 Vision panels	X		
2.34	(H) Flexible hydraulic hose & fitting assemblies			X			4.4 Hoistway door locking devices	X		
2.35	(H) Supply line & shutoff valve				X		4.5 Access to hoist -way	X		
2.36	(H) Hydraulic cylinders			X			4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS006146	Report Number: 4649753
------------------------------------	-------------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
2.3		PROVIDE GUARD ON LIGHTING
2.11		Label disconnect with use and fed from data
2.35		Shutoff valve required in machine room
2.40		Provide/maintain Firefighters' service monthly check log
5.1		Pit light switch is required to be reachable from the access point and adjacent to pit ladder

Building Owner Information:

Owner Name:	DEPARTMENT OF FINANCE & ADMINISTRATION
Owner Address:	501 N. WEST ST., SUITE 2002
City, State, Zip:	JACKSON, MS 39201
Contact:	DEPARTMENT OF FINANCE & ADMINISTRATION
Signature:	

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Traction - Elevator / Dumbwaiter**

Date of Inspection: 07/18/2023	Conveyance Type: Dumbwaiter		
Inspection Type: <input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649798	

Building Location and Unit Information

Building Name:	DFA GOVERNOR'S MANSION	MS Unit ID Number:	MS006102	Unit Designation:	DW
Address:	300 CAPITOL STREET	Manufacturer:	Other	Installed Year:	1980
City, State, Zip:	JACKSON MS 39201	Speed:	50 fpm	Capacity:	300 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	3
				Openings:	3

(Continuation)

MS Unit ID Number: MS006102	Report Number: 4649798
------------------------------------	-------------------------------

1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device	X			2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting	X			2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records	X		
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing	X		
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors	X			3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space	X			3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles	X			3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control	X			3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23 Suspension rope	X		
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & de ctor sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A

MS Unit ID Number: MS006102	Report Number: 4649798
-----------------------------	------------------------

4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
----------	--------	---------

Building Owner Information:

Owner Name: CAPITOL FACILITIES
Owner Address: 300 CAPITOL
City, State, Zip: JACKSON, MS 39201
Contact: CAPITOL FACILITIES

Signature:

JT By
 PKM

Inspection Company & Inspector's Information:

Company Name: NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address: 11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip: SAINT LOUIS, MO 63146-3216
Inspector QEI #:

Inspector State License #:**Inspector's Signature:**

PKM

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Traction - Elevator / Dumbwaiter**

Date of Inspection: 07/18/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit: MSP-22-59	Report Number: 4649799

Building Location and Unit Information

Building Name:	DFA GOVERNOR'S MANSION	MS Unit ID Number:	MS006103	Unit Designation:	PASS.
Address:	300 CAPITOL STREET	Manufacturer:	MCE	Installed Year:	2022
City, State, Zip:	JACKSON MS 39201	Speed:	100 fpm	Capacity:	2000 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	4
				Openings:	4

(Continuation)

MS Unit ID Number: MS006103	Report Number: 4649799
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device	X			2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting		X		2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records	X		
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing	X		
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors	X			3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space	X			3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles		X		3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space		X		3.14 Hoist-way clearances	X		
2.5 Housekeeping		X		3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control	X			3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23 Suspension rope	X		
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & deflector sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A

MS Unit ID Number: MS006103	Report Number: 4649799
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
1.6	X	Emergency alarm inoperable
2.3		PROVIDE GUARD ON LIGHTS
2.4		NO ACCESS TO MACHINE DUE TO WAY GUARD MOUNTED.
2.5		Remove non-elevator related materials from machine/control room/space

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	300 CAPITOL
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Hydraulic - Elevator or Dumbwaiter**

Date of Inspection: 07/17/2023	Conveyance Type: Passenger Elevator		
Inspection Type: <input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649744	

Building Location and Unit Information

Building Name:	DFA HEBER LADNER BUILDING	MS Unit ID Number:	MS006123	Unit Designation:	1
Address:	401 MISSISSIPPI ST	Manufacturer:	ThyssenKrupp	Installed Year:	2020
City, State, Zip:	JACKSON MS 39201-1004	Speed:	100 fpm	Capacity:	2100 lbs
Contact:	HEBER LADNER BLDG.	Phone:	(769) 245-6329	Stops:	3
				Openings:	3

(Continuation)

MS Unit ID Number: MS006123	Report Number: 4649744
------------------------------------	-------------------------------



1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1 Door reopening device	X			2.38 (H) Roped water hydraulic elevators	X		
1.2 Stop switches	X			2.39 (H) Low oil protection	X		
1.3 Operating control devices	X			2.40 Maintenance records	X		
1.4 Sills & car floor	X			2.41 Static control	X		
1.5 Car lighting & receptacles	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.6 Car emergency signal-lighting	X			3.1 Top-of-car stop switch	X		
1.7 Car door or gate	X			3.2 Car top light & outlet	X		
1.8 Door closing force	X			3.3 Top-of-car operating device	X		
1.9 Power closing of doors or gates	X			3.4 Clearance, refuge space standard railing	X		
1.10 Power opening of doors or gates	X			3.5 Normal terminal stopping devices	X		
1.11 Car vision panels & glass car doors	X			3.6 Final & emergency terminal stopping devices	X		
1.12 Car enclosure	X			3.7 Car leveling & anti-creep devices	X		
1.13 Emergency exit	X			3.8 Top emergency exit	X		
1.14 Ventilation	X			3.9 Floor & emergency identification numbering	X		
1.15 Signs & operating device symbols	X			3.10 Hoist-way construction	X		
1.16 Related load, platform area, & data plate	X			3.11 Hoist-way smoke control (IDPH only)	X		
1.17 Standby power operation	X			3.12 Pipes, wiring & ducts	X		
1.18 Restricted opening of car or hoist-way doors	X			3.13 Windows, projections, recesses, & setbacks	X		
1.19 Car ride	X			3.14 Hoist-way clearances	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.15 Multiple hoist-ways	X		
2.1 Access to Machine Space		X		3.16 Traveling cables & junction boxes	X		
2.2 Headroom	X			3.17 Door & gate equipment	X		
2.3 Lighting & receptacles	X			3.18 Car frame & stiles	X		
2.4 Machine space	X			3.19 Guide rails fastening & equipment	X		
2.5 Housekeeping	X			3.20 Governor rope	X		
2.6 Ventilation	X			3.21 Governor releasing carrier	X		
2.7 Fire extinguisher	X			3.22 Wire rope fastening & hitch plate	X		
2.8 Pipes, wiring, & ducts	X			3.23 Suspension rope	X		
2.9 Guarding of exposed auxiliary equipment	X			3.27 Crosshead data plate & rope data tags	X		
2.10 Numbering of elevators, machines, disconnects	X			3.28 Counterweight & counterweight bu er	X		
2.11 Disconnecting means & control	X			3.29 Counterweight safeties	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.30 (H) Speed test	X		
2.13 Governor, over-speed switch, & seal	X			3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.14 Code data plate	X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.30 (H) Hydraulic power unit	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A
2.31 (H) Relief valves	X			4.1 Car platform guard	X		
2.32 (H) Control valve	X			4.2 Hoist-way doors	X		
2.33 (H) Tanks	X			4.3 Vision panels	X		
2.34 (H) Flexible hydraulic hose & fitting assemblies	X			4.4 Hoistway door locking devices	X		
2.35 (H) Supply line & shutoff valve	X			4.5 Access to hoist -way	X		
2.36 (H) Hydraulic cylinders	X			4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS006123	Report Number: 4649744
------------------------------------	-------------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
2.1		REPAIR LOCK ON MACHINE ROOM DOOR

Building Owner Information:

Owner Name:	HEBER LADNER BLDG.
Owner Address:	501 N. WEST ST., SUITE 2002
City, State, Zip:	JACKSON, MS 39201
Contact:	HEBER LADNER BLDG.
Signature:	 

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Traction - Elevator / Dumbwaiter**

Date of Inspection: 07/18/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649822

Building Location and Unit Information

Building Name:	DFA DEQ 515 AMITE BUILDING	MS Unit ID Number:	MS006109	Unit Designation:	1 PASS.
Address:	515 AMITE	Manufacturer:	Schindler	Installed Year:	1993
City, State, Zip:	JACKSON MS 39201	Speed:	300 fpm	Capacity:	3000 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	6
				Openings:	6

(Continuation)

MS Unit ID Number: MS006109	Report Number: 4649822
------------------------------------	-------------------------------



1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device	X			2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting	X			2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records		X	
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing		X	
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors		X		3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space	X			3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles	X			3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control		X		3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23 Suspension rope		X	
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & deflector sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A

MS Unit ID Number: MS006109	Report Number: 4649822
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
1.18	X	Door restriction required
2.11		110v car light disconnect must be fused and lockable
2.11		PROVIDE SHUNT TRIP DISCONNECT
2.40		Provide/maintain Firefighters' service monthly check log
3.4		Provide standard railing on the car-top that meets the code
3.23	X	Replace suspension ropes due to reduced diameter
5.1	X	Repair/provide pit ladder
5.1		Pit light switch is required to be reachable from the access point and adjacent to pit ladder

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	515 AMITE
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	 

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Traction - Elevator / Dumbwaiter**

Date of Inspection: 07/18/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649826

Building Location and Unit Information

Building Name:	DFA DEQ 515 AMITE BUILDING	MS Unit ID Number:	MS006110	Unit Designation:	2 PASS.
Address:	515 AMITE	Manufacturer:	Schindler	Installed Year:	1993
City, State, Zip:	JACKSON MS 39201	Speed:	300 fpm	Capacity:	3000 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	6
				Openings:	6

(Continuation)


MS Unit ID Number: MS006110	Report Number: 4649826
------------------------------------	-------------------------------

1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device	X			2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting	X			2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records		X	
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing		X	
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors		X		3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space	X			3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts		X	
2.3 Lighting & receptacles	X			3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control		X		3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23 Suspension rope		X	
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & deflector sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A


MS Unit ID Number: MS006110		Report Number: 4649826		
4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
2.11		110v car light disconnect must be fused and lockable
2.40		Provide/maintain Firefighters' service monthly check log
3.4		Provide standard railing on the car-top that meets the code
3.12	X	Provide heat detector within 2' of sprinkler head to initiate power shunt prior to application of sprinkler water in hoistway
3.12		PROVIDE SHUNT TRIP DISCONNECTS
3.23	X	Replace suspension ropes due to reduced diameter
5.1	X	Repair/provide pit ladder
5.1		Pit light switch is required to be reachable from the access point and adjacent to pit ladder

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	515 AMITE
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEY

Commissioner of Insurance
State Fire Marshal

MARK HAIRE

Deputy Commissioner of Insurance



MAILING ADDRESS:

P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474

MISSISSIPPI INSURANCE DEPARTMENT

ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201

Periodic - Traction - Elevator / Dumbwaiter

Date of Inspection: 07/18/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649831

Building Location and Unit Information

Building Name:	DFA DEQ 515 AMITE BUILDING	MS Unit ID Number:	MS006111	Unit Designation:	3 PASS.
Address:	515 AMITE	Manufacturer:	Schindler	Installed Year:	1993
City, State, Zip:	JACKSON MS 39201	Speed:	350 fpm	Capacity:	3500 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	6
				Openings:	6

(Continuation)

MS Unit ID Number:	MS006111	Report Number:	4649831
--------------------	----------	----------------	---------


1. ELEVATOR INSIDE OF CAR			Pass	Fail	N/A	2.22	(T) Motor generator	X			
1.1	Door reopening device		X			2.23	(T) Absorption of regenerated power	X			
1.2	Stop switches		X			2.24	(T) AC drives from a DC source	X			
1.3	Operating control devices		X			2.25	(T) Traction sheaves	X			
1.4	Sills & car floor		X			2.26	(T) Secondary & deflector sheaves	X			
1.5	Car lighting & receptacles		X			2.27	(T) Rope fastenings	X			
1.6	Car emergency signal-lighting		X			2.28	(T) Terminal stopping devices	X			
1.7	Car door or gate		X			2.29	(T) Car & counterweight safeties	X			
1.8	Door closing force		X			2.40	Maintenance records	X			
1.9	Power closing of doors or gates		X			2.41	Static control	X			
1.10	Power opening of doors or gates		X			3. ELEVATOR TOP OF CAR			Pass	Fail	N/A
1.11	Car vision panels & glass car doors		X			3.1	Top-of-car stop switch	X			
1.12	Car enclosure		X			3.2	Car top light & outlet	X			
1.13	Emergency exit		X			3.3	Top-of-car operating device	X			
1.14	Ventilation		X			3.4	Clearance, refuge space standard railing		X		
1.15	Signs & operating device symbols		X			3.5	Normal terminal stopping devices	X			
1.16	Related load, platform area, & data plate		X			3.6	Final & emergency terminal stopping devices	X			
1.17	Standby power operation		X			3.7	Car leveling & anti-creep devices	X			
1.18	Restricted opening of car or hoist-way doors			X		3.8	Top emergency exit	X			
1.19	Car ride		X			3.9	Floor & emergency identification numbering	X			
2. ELEVATOR MACHINE ROOM			Pass	Fail	N/A	3.10	Hoist-way construction	X			
2.1	Access to Machine Space		X			3.11	Hoist-way smoke control (IDPH only)	X			
2.2	Headroom		X			3.12	Pipes, wiring & ducts		X		
2.3	Lighting & receptacles		X			3.13	Windows, projections, recesses, & setbacks	X			
2.4	Machine space		X			3.14	Hoist-way clearances	X			
2.5	Housekeeping		X			3.15	Multiple hoist-ways	X			
2.6	Ventilation		X			3.16	Traveling cables & junction boxes	X			
2.7	Fire extinguisher		X			3.17	Door & gate equipment	X			
2.8	Pipes, wiring, & ducts		X			3.18	Car frame & stiles	X			
2.9	Guarding of exposed auxiliary equipment		X			3.19	Guide rails fastening & equipment	X			
2.10	Numbering of elevators, machines, disconnects		X			3.20	Governor rope	X			
2.11	Disconnecting means & control			X		3.21	Governor releasing carrier	X			
2.12	Controller wiring, fuses, grounding, etc.		X			3.22	Wire rope fastening & hitch plate	X			
2.13	Governor, over-speed switch, & seal		X			3.23	Suspension rope	X			
2.14	Code data plate		X			3.24	(T) Top counterweight clearance	X			
2.15	(T) Static control		X			3.25	(T) Car, overhead, & de ctor sheaves	X			
2.16	(T) Overhead beam & fastenings		X			3.26	(T) Broken rope, chain, or tape switch	X			
2.17	(T) Drive machine brake		X			3.27	Crosshead data plate & rope data tags	X			
2.18	(T) Traction drive machines		X			3.28	Counterweight & counterweight buffer	X			
2.19	(T) Gears, bearings, & flexible coupling		X			3.29	Counterweight safeties	X			
2.20	(T) Winding drum mach & slack cable dev		X			3.33	(T) Compensating ropes & chains	X			
2.21	(T) Belt or chain-drive machine		X			4. ELEVATOR OUTSIDE HOIST-WAY			Pass	Fail	N/A

MS Unit ID Number: MS006111	Report Number: 4649831
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
1.18	X	Door restriction required
2.11		Provide a car light disconnect
2.11		Label disconnect with use and fed from data
2.11		PROVIDE SHUNT TRIP DISCONNECT
3.4		Provide standard railing on the car-top that meets the code
3.12	X	Provide heat detector within 2' of sprinkler head to initiate power shunt prior to application of sprinkler water in hoistway
5.1	X	Pit stop switch is required to be reachable from the hoistway access point and adjacent to pit ladder
5.1		Pit light switch is required to be reachable from the access point and adjacent to pit ladder

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	515 AMITE
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Hydraulic - Elevator or Dumbwaiter**

Date of Inspection: 07/18/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649775

Building Location and Unit Information

Building Name:	DFA OLD CAPITOL BUILDING	MS Unit ID Number:	MS006100	Unit Designation:	PASS.
Address:	100 STATE STREET	Manufacturer:	Schindler	Installed Year:	2008
City, State, Zip:	JACKSON MS 39201	Speed:	150 fpm	Capacity:	4000 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	3
				Openings:	3

(Continuation)

MS Unit ID Number: MS006100	Report Number: 4649775
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR				Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1	Door reopening device				X		2.38 (H) Roped water hydraulic elevators	X		
1.2	Stop switches			X			2.39 (H) Low oil protection	X		
1.3	Operating control devices			X			2.40 Maintenance records	X		
1.4	Sills & car floor			X			2.41 Static control	X		
1.5	Car lighting & receptacles			X			3. ELEVATOR TOP OF CAR			
1.6	Car emergency signal-lighting			X			3.1 Top-of-car stop switch	X		
1.7	Car door or gate			X			3.2 Car top light & outlet	X		
1.8	Door closing force			X			3.3 Top-of-car operating device	X		
1.9	Power closing of doors or gates			X			3.4 Clearance, refuge space standard railing	X		
1.10	Power opening of doors or gates			X			3.5 Normal terminal stopping devices	X		
1.11	Car vision panels & glass car doors			X			3.6 Final & emergency terminal stopping devices	X		
1.12	Car enclosure			X			3.7 Car leveling & anti-creep devices	X		
1.13	Emergency exit			X			3.8 Top emergency exit	X		
1.14	Ventilation			X			3.9 Floor & emergency identification numbering	X		
1.15	Signs & operating device symbols			X			3.10 Hoist-way construction	X		
1.16	Related load, platform area, & data plate			X			3.11 Hoist-way smoke control (IDPH only)	X		
1.17	Standby power operation			X			3.12 Pipes, wiring & ducts	X		
1.18	Restricted opening of car or hoist-way doors				X		3.13 Windows, projections, recesses, & setbacks	X		
1.19	Car ride			X			3.14 Hoist-way clearances	X		
2. ELEVATOR MACHINE ROOM				Pass	Fail	N/A	3.15 Multiple hoist-ways	X		
2.1	Access to Machine Space			X			3.16 Traveling cables & junction boxes	X		
2.2	Headroom			X			3.17 Door & gate equipment	X		
2.3	Lighting & receptacles			X			3.18 Car frame & stiles	X		
2.4	Machine space			X			3.19 Guide rails fastening & equipment	X		
2.5	Housekeeping				X		3.20 Governor rope	X		
2.6	Ventilation			X			3.21 Governor releasing carrier	X		
2.7	Fire extinguisher			X			3.22 Wire rope fastening & hitch plate	X		
2.8	Pipes, wiring, & ducts			X			3.23 Suspension rope	X		
2.9	Guarding of exposed auxiliary equipment			X			3.27 Crosshead data plate & rope data tags	X		
2.10	Numbering of elevators, machines, disconnects			X			3.28 Counterweight & counterweight bu er	X		
2.11	Disconnecting means & control				X		3.29 Counterweight safeties	X		
2.12	Controller wiring, fuses, grounding, etc.			X			3.30 (H) Speed test	X		
2.13	Governor, over-speed switch, & seal			X			3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.14	Code data plate			X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.30	(H) Hydraulic power unit			X			4. ELEVATOR OUTSIDE HOIST-WAY			
2.31	(H) Relief valves			X			4.1 Car platform guard	X		
2.32	(H) Control valve			X			4.2 Hoist-way doors	X		
2.33	(H) Tanks			X			4.3 Vision panels	X		
2.34	(H) Flexible hydraulic hose & fitting assemblies			X			4.4 Hoistway door locking devices	X		
2.35	(H) Supply line & shutoff valve			X			4.5 Access to hoist -way	X		
2.36	(H) Hydraulic cylinders			X			4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS006100	Report Number: 4649775
------------------------------------	-------------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
1.1		ADJUST DOOR TORQUE
1.18	X	Door restriction required
2.5		Remove non-elevator related materials from machine/control room/space
2.11		Label disconnect with use and fed from data
5.1	X	Pit stop switch is required to be reachable from the hoistway access point and adjacent to pit ladder
5.1		Pit light switch is required to be reachable from the access point and adjacent to pit ladder

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	100 STATE STREET
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEY

Commissioner of Insurance
State Fire Marshal

MARK HAIRE

Deputy Commissioner of Insurance



MAILING ADDRESS:

P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474

MISSISSIPPI INSURANCE DEPARTMENT

ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201

Periodic - Traction - Elevator / Dumbwaiter

Date of Inspection: 07/18/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649951

Building Location and Unit Information

Building Name:	DFA 301 BLDG	MS Unit ID Number:	MS006124	Unit Designation:	1
Address:	301 N LAMAR ST	Manufacturer:	ThyssenKrupp	Installed Year:	2013
City, State, Zip:	JACKSON MS 39201-1404	Speed:	150 fpm	Capacity:	3500 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	6
				Openings:	6

(Continuation)

MS Unit ID Number: MS006124	Report Number: 4649951
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device	X			2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting	X			2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records		X	
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing	X		
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors	X			3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space		X		3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles	X			3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control	X			3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23 Suspension rope	X		
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & de ctor sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A

MS Unit ID Number: MS006124	Report Number: 4649951
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
2.1		Machine room door is required to be self-locking
2.40		Provide/maintain Firefighters' service monthly check log

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	301 N LAMAR ST.
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Traction - Elevator / Dumbwaiter**

Date of Inspection: 07/18/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649955

Building Location and Unit Information

Building Name:	DFA 301 BLDG	MS Unit ID Number:	MS006125	Unit Designation:	2
Address:	301 N LAMAR ST	Manufacturer:	ThyssenKrupp	Installed Year:	1986
City, State, Zip:	JACKSON MS 39201-1404	Speed:	150 fpm	Capacity:	3500 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	6
				Openings:	6

(Continuation)

MS Unit ID Number: MS006125	Report Number: 4649955
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device	X			2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting	X			2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records		X	
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing	X		
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors	X			3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space		X		3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles	X			3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control	X			3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23 Suspension rope	X		
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & deflector sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A

MS Unit ID Number: MS006125	Report Number: 4649955
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
2.1		machine room door is required to be self-closing
2.40		Provide/maintain Firefighters' service monthly check log
5.1		Pit light switch is required to be reachable from the access point and adjacent to pit ladder
5.1		PROVIDE NON COMBUSTIBLE SUMP HOLE COVER

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	301 N LAMAR ST.
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEY

Commissioner of Insurance
State Fire Marshal

MARK HAIRE

Deputy Commissioner of Insurance



MAILING ADDRESS:

P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474

MISSISSIPPI INSURANCE DEPARTMENT

ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201

Periodic - Traction - Elevator / Dumbwaiter

Date of Inspection: 07/18/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649934

Building Location and Unit Information

Building Name:	DFA ROBERT E. LEE BUILDING	MS Unit ID Number:	MS006126	Unit Designation:	#1
Address:	239 LAMAR STREET	Manufacturer:	ThyssenKrupp	Installed Year:	2017
City, State, Zip:	JACKSON MS 39201	Speed:	500 fpm	Capacity:	3000 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	13
				Openings:	13

(Continuation)

MS Unit ID Number:	MS006126	Report Number:	4649934
--------------------	----------	----------------	---------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device	X			2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting	X			2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records		X	
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing	X		
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors	X			3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space	X			3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles	X			3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control	X			3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23 Suspension rope	X		
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & de ctor sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A

MS Unit ID Number: MS006126	Report Number: 4649934
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
2.40		Provide/maintain Firefighters' service monthly check log
5.1	X	Pit stop switch is required to be reachable from the hoistway access point and adjacent to pit ladder

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	501 N WEST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Traction - Elevator / Dumbwaiter**

Date of Inspection: 07/18/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649937

Building Location and Unit Information

Building Name:	DFA ROBERT E. LEE BUILDING	MS Unit ID Number:	MS006127	Unit Designation:	#2
Address:	239 LAMAR STREET	Manufacturer:	ThyssenKrupp	Installed Year:	2017
City, State, Zip:	JACKSON MS 39201	Speed:	500 fpm	Capacity:	3500 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	12
				Openings:	12

(Continuation)

MS Unit ID Number: MS006127	Report Number: 4649937
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device	X			2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting	X			2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records		X	
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing	X		
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors	X			3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space	X			3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles	X			3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control	X			3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23 Suspension rope	X		
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & deflector sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A

MS Unit ID Number: MS006127	Report Number: 4649937
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
2.40		Provide/maintain Firefighters' service monthly check log

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	501 N WEST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Traction - Elevator / Dumbwaiter**

Date of Inspection: 07/18/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649941

Building Location and Unit Information

Building Name:	DFA ROBERT E. LEE BUILDING	MS Unit ID Number:	MS006128	Unit Designation:	#3
Address:	239 LAMAR STREET	Manufacturer:	ThyssenKrupp	Installed Year:	2017
City, State, Zip:	JACKSON MS 39201	Speed:	500 fpm	Capacity:	3500 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	12
				Openings:	12

(Continuation)

MS Unit ID Number: MS006128	Report Number: 4649941
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device	X			2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting	X			2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records		X	
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing	X		
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors	X			3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space	X			3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles	X			3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control	X			3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23 Suspension rope	X		
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & deflector sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A

MS Unit ID Number: MS006128	Report Number: 4649941
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
2.40		Provide/maintain Firefighters' service monthly check log

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	501 N WEST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Traction - Elevator / Dumbwaiter**

Date of Inspection: 07/18/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649932

Building Location and Unit Information

Building Name:	DFA ROBERT E. LEE BUILDING	MS Unit ID Number:	MS006129	Unit Designation:	4
Address:	239 LAMAR STREET	Manufacturer:	Otis	Installed Year:	1960
City, State, Zip:	JACKSON MS 39201	Speed:	500 fpm	Capacity:	3000 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	13
				Openings:	13

(Continuation)

MS Unit ID Number: MS006129	Report Number: 4649932
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22	(T) Motor generator	X		
1.1 Door reopening device	X			2.23	(T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24	(T) AC drives from a DC source	X		
1.3 Operating control devices		X		2.25	(T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26	(T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27	(T) Rope fastenings	X		
1.6 Car emergency signal-lighting		X		2.28	(T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29	(T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40	Maintenance records	X		
1.9 Power closing of doors or gates	X			2.41	Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A	
1.11 Car vision panels & glass car doors	X			3.1	Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2	Car top light & outlet	X		
1.13 Emergency exit	X			3.3	Top-of-car operating device		X	
1.14 Ventilation	X			3.4	Clearance, refuge space standard railing	X		
1.15 Signs & operating device symbols	X			3.5	Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6	Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7	Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors	X			3.8	Top emergency exit		X	
1.19 Car ride	X			3.9	Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10	Hoist-way construction	X		
2.1 Access to Machine Space	X			3.11	Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12	Pipes, wiring & ducts	X		
2.3 Lighting & receptacles	X			3.13	Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14	Hoist-way clearances	X		
2.5 Housekeeping	X			3.15	Multiple hoist-ways	X		
2.6 Ventilation	X			3.16	Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17	Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18	Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19	Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20	Governor rope	X		
2.11 Disconnecting means & control	X			3.21	Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22	Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23	Suspension rope	X		
2.14 Code data plate	X			3.24	(T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25	(T) Car, overhead, & de ctor sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26	(T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27	Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28	Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29	Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33	(T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A	

MS Unit ID Number: MS006129	Report Number: 4649932
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
1.3		REPAIR 4TH FLOOR HALL PUSH BUTTON STATION
1.6		PROVIDE ALARM BELL
3.3	X	Top-of-car operating device required
3.8		RELPAIR ESCAPE HATCH

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	501 N WEST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEY

Commissioner of Insurance
State Fire Marshal

MARK HAIRE

Deputy Commissioner of Insurance



MAILING ADDRESS:

P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474

MISSISSIPPI INSURANCE DEPARTMENT

ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201

Periodic - Traction - Elevator / Dumbwaiter

Date of Inspection: 07/18/2023	Conveyance Type: Passenger Elevator	
Inspection Type: <input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649929

Building Location and Unit Information

Building Name: DFA ROBERT E. LEE BUILDING	MS Unit ID Number: MS006130	Unit Designation: 1 PARKING
Address: 239 LAMAR STREET	Manufacturer: Dover	Installed Year: 2005
City, State, Zip: JACKSON MS 39201	Speed: 350 fpm	Capacity: 2500 lbs
Contact: CAPITOL FACILITIES	Phone: (769) 245-6329	Stops: 8
		Openings: 8

(Continuation)

MS Unit ID Number: MS006130	Report Number: 4649929
-----------------------------	------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device	X			2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting	X			2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records	X		
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing	X		
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors		X		3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space	X			3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles	X			3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space		X		3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control	X			3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23 Suspension rope		X	
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & de ctor sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A

MS Unit ID Number: MS006130	Report Number: 4649929
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
1.18	X	Door restriction required
2.4		REPAIR AIR CONDITIONING UNIT
3.23	X	Replace suspension ropes due to reduced diameter
5.1		PROVIDE PIT LIGHTING

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	501 N WEST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEY

Commissioner of Insurance
State Fire Marshal

MARK HAIRE

Deputy Commissioner of Insurance



MAILING ADDRESS:

P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474

MISSISSIPPI INSURANCE DEPARTMENT

ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201

Periodic - Traction - Elevator / Dumbwaiter

Date of Inspection: 07/19/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649982

Building Location and Unit Information

Building Name:	DFA SILLARS BUILDING	MS Unit ID Number:	MS006135	Unit Designation:	1
Address:	550 HIGH ST	Manufacturer:	Otis	Installed Year:	1998
City, State, Zip:	JACKSON MS 39201-1111	Speed:	800 fpm	Capacity:	3000 lbs
Contact:	DEPARTMENT OF FINANCE & Phone: (769) 245-6329	Stops:	20	Openings:	20

(Continuation)

MS Unit ID Number:	MS006135	Report Number:	4649982
--------------------	----------	----------------	---------



1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device	X			2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting	X			2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records		X	
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing	X		
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors		X		3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space	X			3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles	X			3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control	X			3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23 Suspension rope	X		
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & de ctor sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A

MS Unit ID Number: MS006135	Report Number: 4649982
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
1.18	X	Door restriction required
2.40		Provide/maintain Firefighters' service monthly check log

Building Owner Information:

Owner Name:	DEPARTMENT OF FINANCE & ADMINISTRATION
Owner Address:	501 N. WEST ST., SUITE 2002
City, State, Zip:	JACKSON, MS 39201
Contact:	DEPARTMENT OF FINANCE & ADMINISTRATION
Signature:	 

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEY

Commissioner of Insurance
State Fire Marshal

MARK HAIRE

Deputy Commissioner of Insurance



MAILING ADDRESS:

P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474

MISSISSIPPI INSURANCE DEPARTMENT

ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201

Periodic - Traction - Elevator / Dumbwaiter

Date of Inspection: 07/19/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649983

Building Location and Unit Information

Building Name:	DFA SILLARS BUILDING	MS Unit ID Number:	MS006136	Unit Designation:	2
Address:	550 HIGH ST	Manufacturer:	Otis	Installed Year:	1998
City, State, Zip:	JACKSON MS 39201-1111	Speed:	800 fpm	Capacity:	3000 lbs
Contact:	DEPARTMENT OF FINANCE & Phone: (769) 245-6329	Stops:	20	Openings:	20

(Continuation)

MS Unit ID Number:	MS006136	Report Number:	4649983
--------------------	----------	----------------	---------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device	X			2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting	X			2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records		X	
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing	X		
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors		X		3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space	X			3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles	X			3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control	X			3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23 Suspension rope	X		
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & de ctor sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A

MS Unit ID Number: MS006136	Report Number: 4649983
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
1.18	X	Door restriction required
2.40		Provide/maintain Firefighters' service monthly check log

Building Owner Information:

Owner Name:	DEPARTMENT OF FINANCE & ADMINISTRATION
Owner Address:	501 N. WEST ST., SUITE 2002
City, State, Zip:	JACKSON, MS 39201
Contact:	DEPARTMENT OF FINANCE & ADMINISTRATION
Signature:	

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Traction - Elevator / Dumbwaiter**

Date of Inspection: 07/19/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649979

Building Location and Unit Information

Building Name:	DFA SILLARS BUILDING	MS Unit ID Number:	MS006137	Unit Designation:	3
Address:	550 HIGH ST	Manufacturer:	Otis	Installed Year:	1998
City, State, Zip:	JACKSON MS 39201-1111	Speed:	800 fpm	Capacity:	3000 lbs
Contact:	DEPARTMENT OF FINANCE & Phone: (769) 245-6329	Stops:	20	Openings:	20

(Continuation)

MS Unit ID Number:	MS006137	Report Number:	4649979
--------------------	----------	----------------	---------



1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device	X			2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting	X			2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records		X	
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing	X		
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors		X		3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space	X			3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles	X			3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control	X			3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23 Suspension rope	X		
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & de ctor sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A

MS Unit ID Number: MS006137	Report Number: 4649979
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
1.18	X	Door restriction required
2.40		Provide/maintain Firefighters' service monthly check log

Building Owner Information:

Owner Name:	DEPARTMENT OF FINANCE & ADMINISTRATION
Owner Address:	501 N. WEST ST., SUITE 2002
City, State, Zip:	JACKSON, MS 39201
Contact:	DEPARTMENT OF FINANCE & ADMINISTRATION
Signature:	 

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Traction - Elevator / Dumbwaiter**

Date of Inspection: 07/19/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649976

Building Location and Unit Information

Building Name:	DFA SILLARS BUILDING	MS Unit ID Number:	MS006140	Unit Designation:	6
Address:	550 HIGH ST	Manufacturer:	Otis	Installed Year:	1998
City, State, Zip:	JACKSON MS 39201-1111	Speed:	800 fpm	Capacity:	3000 lbs
Contact:	DEPARTMENT OF FINANCE & Phone: (769) 245-6329	Stops:	20	Openings:	20

(Continuation)

MS Unit ID Number: MS006140	Report Number: 4649976
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device	X			2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting		X		2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records		X	
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing	X		
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors		X		3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space		X		3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles		X		3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control	X			3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23 Suspension rope	X		
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & de ctor sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A

MS Unit ID Number: MS006140	Report Number: 4649976
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
1.6	X	Emergency phone not working
1.18	X	Door restriction required
2.1		Machine room door is required to be self-locking
2.1		machine room door is required to be self-closing
2.3		REPAIR LIGHTING. REPAIR LIGHTING
2.40		Provide/maintain Firefighters' service monthly check log

Building Owner Information:

Owner Name:	DEPARTMENT OF FINANCE & ADMINISTRATION
Owner Address:	501 N. WEST ST., SUITE 2002
City, State, Zip:	JACKSON, MS 39201
Contact:	DEPARTMENT OF FINANCE & ADMINISTRATION
Signature:	

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Hydraulic - Elevator or Dumbwaiter**

Date of Inspection: 07/19/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649971

Building Location and Unit Information

Building Name:	DFA SILLARS BUILDING CAFE	MS Unit ID Number:	MS006141	Unit Designation:	CAFE
Address:	550 HIGH STREET	Manufacturer:	ThyssenKrupp	Installed Year:	2007
City, State, Zip:	JACKSON MS 39201	Speed:	150 fpm	Capacity:	2500 lbs
Contact:	DEPARTMENT OF FINANCE AND	Phone:	(769) 245-6329	Stops:	2
				Openings:	2

(Continuation)

MS Unit ID Number: MS006141	Report Number: 4649971
------------------------------------	-------------------------------



1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1 Door reopening device	X			2.38 (H) Roped water hydraulic elevators	X		
1.2 Stop switches	X			2.39 (H) Low oil protection	X		
1.3 Operating control devices	X			2.40 Maintenance records	X		
1.4 Sills & car floor	X			2.41 Static control	X		
1.5 Car lighting & receptacles	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.6 Car emergency signal-lighting	X			3.1 Top-of-car stop switch	X		
1.7 Car door or gate	X			3.2 Car top light & outlet	X		
1.8 Door closing force	X			3.3 Top-of-car operating device	X		
1.9 Power closing of doors or gates	X			3.4 Clearance, refuge space standard railing	X		
1.10 Power opening of doors or gates	X			3.5 Normal terminal stopping devices	X		
1.11 Car vision panels & glass car doors	X			3.6 Final & emergency terminal stopping devices	X		
1.12 Car enclosure	X			3.7 Car leveling & anti-creep devices	X		
1.13 Emergency exit	X			3.8 Top emergency exit	X		
1.14 Ventilation	X			3.9 Floor & emergency identification numbering	X		
1.15 Signs & operating device symbols	X			3.10 Hoist-way construction	X		
1.16 Related load, platform area, & data plate	X			3.11 Hoist-way smoke control (IDPH only)	X		
1.17 Standby power operation	X			3.12 Pipes, wiring & ducts	X		
1.18 Restricted opening of car or hoist-way doors	X			3.13 Windows, projections, recesses, & setbacks	X		
1.19 Car ride	X			3.14 Hoist-way clearances	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.15 Multiple hoist-ways	X		
2.1 Access to Machine Space	X			3.16 Traveling cables & junction boxes	X		
2.2 Headroom	X			3.17 Door & gate equipment	X		
2.3 Lighting & receptacles		X		3.18 Car frame & stiles	X		
2.4 Machine space	X			3.19 Guide rails fastening & equipment	X		
2.5 Housekeeping	X			3.20 Governor rope	X		
2.6 Ventilation	X			3.21 Governor releasing carrier	X		
2.7 Fire extinguisher	X			3.22 Wire rope fastening & hitch plate	X		
2.8 Pipes, wiring, & ducts	X			3.23 Suspension rope	X		
2.9 Guarding of exposed auxiliary equipment	X			3.27 Crosshead data plate & rope data tags	X		
2.10 Numbering of elevators, machines, disconnects	X			3.28 Counterweight & counterweight bu er	X		
2.11 Disconnecting means & control		X		3.29 Counterweight safeties	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.30 (H) Speed test	X		
2.13 Governor, over-speed switch, & seal	X			3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.14 Code data plate	X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.30 (H) Hydraulic power unit	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A
2.31 (H) Relief valves	X			4.1 Car platform guard	X		
2.32 (H) Control valve	X			4.2 Hoist-way doors	X		
2.33 (H) Tanks	X			4.3 Vision panels	X		
2.34 (H) Flexible hydraulic hose & fitting assemblies	X			4.4 Hoistway door locking devices	X		
2.35 (H) Supply line & shutoff valve	X			4.5 Access to hoist -way	X		
2.36 (H) Hydraulic cylinders	X			4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS006141	Report Number: 4649971
------------------------------------	-------------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
2.3		PROVIDE GUARD ON LIGHTS
2.11		Label disconnect with use and fed from data
5.1		Pit light switch is required to be reachable from the access point and adjacent to pit ladder

Building Owner Information:

Owner Name:	DEPARTMENT OF FINANCE AND ADMINISTRATION
Owner Address:	501 N. WEST ST., SUITE 2002
City, State, Zip:	JACKSON, MS 39201
Contact:	DEPARTMENT OF FINANCE AND ADMINISTRATION
Signature:	 

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Hydraulic - Elevator or Dumbwaiter**

Date of Inspection: 07/19/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649966

Building Location and Unit Information

Building Name:	DFA SILLARS PARKING GARAGE	MS Unit ID Number:	MS006117	Unit Designation:	1
Address:	550 HIGH STREET	Manufacturer:	ThyssenKrupp	Installed Year:	2007
City, State, Zip:	JACKSON MS 39201	Speed:	350 fpm	Capacity:	3500 lbs
Contact:	DEPARTMENT OF FINANCE & Phone: (769) 245-6329	Stops:	7	Openings:	7

(Continuation)

MS Unit ID Number: MS006117	Report Number: 4649966
------------------------------------	-------------------------------



1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1 Door reopening device	X			2.38 (H) Roped water hydraulic elevators	X		
1.2 Stop switches	X			2.39 (H) Low oil protection	X		
1.3 Operating control devices	X			2.40 Maintenance records	X		
1.4 Sills & car floor	X			2.41 Static control	X		
1.5 Car lighting & receptacles	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.6 Car emergency signal-lighting	X			3.1 Top-of-car stop switch	X		
1.7 Car door or gate	X			3.2 Car top light & outlet	X		
1.8 Door closing force	X			3.3 Top-of-car operating device	X		
1.9 Power closing of doors or gates	X			3.4 Clearance, refuge space standard railing	X		
1.10 Power opening of doors or gates	X			3.5 Normal terminal stopping devices	X		
1.11 Car vision panels & glass car doors	X			3.6 Final & emergency terminal stopping devices	X		
1.12 Car enclosure	X			3.7 Car leveling & anti-creep devices	X		
1.13 Emergency exit	X			3.8 Top emergency exit	X		
1.14 Ventilation	X			3.9 Floor & emergency identification numbering	X		
1.15 Signs & operating device symbols	X			3.10 Hoist-way construction	X		
1.16 Related load, platform area, & data plate	X			3.11 Hoist-way smoke control (IDPH only)	X		
1.17 Standby power operation	X			3.12 Pipes, wiring & ducts	X		
1.18 Restricted opening of car or hoist-way doors	X			3.13 Windows, projections, recesses, & setbacks	X		
1.19 Car ride	X			3.14 Hoist-way clearances	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.15 Multiple hoist-ways	X		
2.1 Access to Machine Space		X		3.16 Traveling cables & junction boxes	X		
2.2 Headroom	X			3.17 Door & gate equipment	X		
2.3 Lighting & receptacles		X		3.18 Car frame & stiles	X		
2.4 Machine space	X			3.19 Guide rails fastening & equipment	X		
2.5 Housekeeping	X			3.20 Governor rope	X		
2.6 Ventilation	X			3.21 Governor releasing carrier	X		
2.7 Fire extinguisher	X			3.22 Wire rope fastening & hitch plate	X		
2.8 Pipes, wiring, & ducts	X			3.23 Suspension rope	X		
2.9 Guarding of exposed auxiliary equipment	X			3.27 Crosshead data plate & rope data tags	X		
2.10 Numbering of elevators, machines, disconnects	X			3.28 Counterweight & counterweight bu er	X		
2.11 Disconnecting means & control	X			3.29 Counterweight safeties	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.30 (H) Speed test	X		
2.13 Governor, over-speed switch, & seal	X			3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.14 Code data plate	X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.30 (H) Hydraulic power unit	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A
2.31 (H) Relief valves	X			4.1 Car platform guard	X		
2.32 (H) Control valve	X			4.2 Hoist-way doors	X		
2.33 (H) Tanks	X			4.3 Vision panels	X		
2.34 (H) Flexible hydraulic hose & fitting assemblies	X			4.4 Hoistway door locking devices	X		
2.35 (H) Supply line & shutoff valve	X			4.5 Access to hoist -way	X		
2.36 (H) Hydraulic cylinders	X			4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS006117	Report Number: 4649966
------------------------------------	-------------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
2.1		machine room door is required to be self-closing
2.3		PROVIDE GUARD ON LIGHTS

Building Owner Information:

Owner Name:	DEPARTMENT OF FINANCE & ADMINISTRATION
Owner Address:	501 N. WEST ST., SUITE 2002
City, State, Zip:	JACKSON, MS 39201
Contact:	DEPARTMENT OF FINANCE & ADMINISTRATION
Signature:	 

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEY

Commissioner of Insurance
State Fire Marshal

MARK HAIRE

Deputy Commissioner of Insurance



MAILING ADDRESS:

P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474

MISSISSIPPI INSURANCE DEPARTMENT

ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201

Periodic - Traction - Elevator / Dumbwaiter

Date of Inspection: 07/19/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649969

Building Location and Unit Information

Building Name:	DFA SILLARS PARKING GARAGE	MS Unit ID Number:	MS006118	Unit Designation:	2
Address:	550 HIGH STREET	Manufacturer:	ThyssenKrupp	Installed Year:	2007
City, State, Zip:	JACKSON MS 39201	Speed:	350 fpm	Capacity:	3500 lbs
Contact:	DEPARTMENT OF FINANCE & Phone: (769) 245-6329	Stops:	7	Openings:	7

(Continuation)

MS Unit ID Number: MS006118	Report Number: 4649969
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device	X			2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting	X			2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records	X		
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing	X		
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors	X			3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space		X		3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles		X		3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control	X			3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23 Suspension rope	X		
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & de ctor sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A

MS Unit ID Number: MS006118	Report Number: 4649969
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
2.1		machine room door is required to be self-closing
2.3		PROVIDE GUARD ON LIGHTS

Building Owner Information:

Owner Name:	DEPARTMENT OF FINANCE & ADMINISTRATION
Owner Address:	501 N. WEST ST., SUITE 2002
City, State, Zip:	JACKSON, MS 39201
Contact:	DEPARTMENT OF FINANCE & ADMINISTRATION
Signature:	

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Traction - Elevator / Dumbwaiter**

Date of Inspection: 07/17/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit: MSP-20-175	Report Number: 4640723

Building Location and Unit Information

Building Name:	DFA NEW CAPITOL BUILDING	MS Unit ID Number:	MS006120	Unit Designation:	AUTOMATIC
Address:	400 HIGH STREET	Manufacturer:	MCE	Installed Year:	1950
City, State, Zip:	JACKSON MS 39201	Speed:	200 fpm	Capacity:	2500 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	4
				Openings:	4

(Continuation)

MS Unit ID Number: MS006120	Report Number: 4640723
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A			
1.1 Door reopening device	X			2.22 (T) Motor generator	X	
1.2 Stop switches	X			2.23 (T) Absorption of regenerated power	X	
1.3 Operating control devices	X			2.24 (T) AC drives from a DC source	X	
1.4 Sills & car floor	X			2.25 (T) Traction sheaves	X	
1.5 Car lighting & receptacles	X			2.26 (T) Secondary & deflector sheaves	X	
1.6 Car emergency signal-lighting	X			2.27 (T) Rope fastenings	X	
1.7 Car door or gate	X			2.28 (T) Terminal stopping devices	X	
1.8 Door closing force	X			2.29 (T) Car & counterweight safeties	X	
1.9 Power closing of doors or gates	X			2.40 Maintenance records	X	
1.10 Power opening of doors or gates	X			2.41 Static control	X	
1.11 Car vision panels & glass car doors	X			3. ELEVATOR TOP OF CAR	Pass	Fail
1.12 Car enclosure	X			3.1 Top-of-car stop switch	X	
1.13 Emergency exit	X			3.2 Car top light & outlet	X	
1.14 Ventilation	X			3.3 Top-of-car operating device	X	
1.15 Signs & operating device symbols	X			3.4 Clearance, refuge space standard railing	X	
1.16 Related load, platform area, & data plate	X			3.5 Normal terminal stopping devices	X	
1.17 Standby power operation	X			3.6 Final & emergency terminal stopping devices	X	
1.18 Restricted opening of car or hoist-way doors	X			3.7 Car leveling & anti-creep devices	X	
1.19 Car ride	X			3.8 Top emergency exit	X	
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.9 Floor & emergency identification numbering	X	
2.1 Access to Machine Space		X		3.10 Hoist-way construction	X	
2.2 Headroom	X			3.11 Hoist-way smoke control (IDPH only)	X	
2.3 Lighting & receptacles	X			3.12 Pipes, wiring & ducts	X	
2.4 Machine space	X			3.13 Windows, projections, recesses, & setbacks	X	
2.5 Housekeeping		X		3.14 Hoist-way clearances	X	
2.6 Ventilation	X			3.15 Multiple hoist-ways	X	
2.7 Fire extinguisher	X			3.16 Traveling cables & junction boxes	X	
2.8 Pipes, wiring, & ducts	X			3.17 Door & gate equipment	X	
2.9 Guarding of exposed auxiliary equipment	X			3.18 Car frame & stiles	X	
2.10 Numbering of elevators, machines, disconnects	X			3.19 Guide rails fastening & equipment	X	
2.11 Disconnecting means & control	X			3.20 Governor rope	X	
2.12 Controller wiring, fuses, grounding, etc.	X			3.21 Governor releasing carrier	X	
2.13 Governor, over-speed switch, & seal	X			3.22 Wire rope fastening & hitch plate	X	
2.14 Code data plate	X			3.23 Suspension rope	X	
2.15 (T) Static control	X			3.24 (T) Top counterweight clearance	X	
2.16 (T) Overhead beam & fastenings	X			3.25 (T) Car, overhead, & de ctor sheaves	X	
2.17 (T) Drive machine brake	X			3.26 (T) Broken rope, chain, or tape switch	X	
2.18 (T) Traction drive machines	X			3.27 Crosshead data plate & rope data tags	X	
2.19 (T) Gears, bearings, & flexible coupling	X			3.28 Counterweight & counterweight buffer	X	
2.20 (T) Winding drum mach & slack cable dev	X			3.29 Counterweight safeties	X	
2.21 (T) Belt or chain-drive machine	X			3.33 (T) Compensating ropes & chains	X	
				4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail

MS Unit ID Number: MS006120	Report Number: 4640723
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
2.1		Machine room door is required to be self-locking
2.5		Remove non-elevator related materials from machine/control room/space

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	400 HIGH
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Hydraulic - Elevator or Dumbwaiter**

Date of Inspection: 07/17/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4640765

Building Location and Unit Information

Building Name:	DFA NEW CAPITOL BUILDING	MS Unit ID Number:	MS006121	Unit Designation:	GOVERNORS
Address:	400 HIGH STREET	Manufacturer:	Otis	Installed Year:	1979
City, State, Zip:	JACKSON MS 39201	Speed:	100 fpm	Capacity:	1500 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	2
				Openings:	2

(Continuation)

MS Unit ID Number: MS006121	Report Number: 4640765
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1 Door reopening device	X			2.38 (H) Roped water hydraulic elevators	X		
1.2 Stop switches	X			2.39 (H) Low oil protection	X		
1.3 Operating control devices	X			2.40 Maintenance records	X		
1.4 Sills & car floor	X			2.41 Static control	X		
1.5 Car lighting & receptacles	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.6 Car emergency signal-lighting		X		3.1 Top-of-car stop switch	X		
1.7 Car door or gate	X			3.2 Car top light & outlet	X		
1.8 Door closing force	X			3.3 Top-of-car operating device	X		
1.9 Power closing of doors or gates	X			3.4 Clearance, refuge space standard railing	X		
1.10 Power opening of doors or gates	X			3.5 Normal terminal stopping devices	X		
1.11 Car vision panels & glass car doors	X			3.6 Final & emergency terminal stopping devices	X		
1.12 Car enclosure	X			3.7 Car leveling & anti-creep devices	X		
1.13 Emergency exit	X			3.8 Top emergency exit	X		
1.14 Ventilation	X			3.9 Floor & emergency identification numbering	X		
1.15 Signs & operating device symbols	X			3.10 Hoist-way construction	X		
1.16 Related load, platform area, & data plate	X			3.11 Hoist-way smoke control (IDPH only)	X		
1.17 Standby power operation	X			3.12 Pipes, wiring & ducts	X		
1.18 Restricted opening of car or hoist-way doors	X			3.13 Windows, projections, recesses, & setbacks	X		
1.19 Car ride	X			3.14 Hoist-way clearances	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.15 Multiple hoist-ways	X		
2.1 Access to Machine Space		X		3.16 Traveling cables & junction boxes	X		
2.2 Headroom	X			3.17 Door & gate equipment	X		
2.3 Lighting & receptacles		X		3.18 Car frame & stiles	X		
2.4 Machine space	X			3.19 Guide rails fastening & equipment	X		
2.5 Housekeeping		X		3.20 Governor rope	X		
2.6 Ventilation	X			3.21 Governor releasing carrier	X		
2.7 Fire extinguisher	X			3.22 Wire rope fastening & hitch plate	X		
2.8 Pipes, wiring, & ducts	X			3.23 Suspension rope	X		
2.9 Guarding of exposed auxiliary equipment	X			3.27 Crosshead data plate & rope data tags	X		
2.10 Numbering of elevators, machines, disconnects	X			3.28 Counterweight & counterweight bu er	X		
2.11 Disconnecting means & control		X		3.29 Counterweight safeties	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.30 (H) Speed test	X		
2.13 Governor, over-speed switch, & seal	X			3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.14 Code data plate	X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.30 (H) Hydraulic power unit	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A
2.31 (H) Relief valves	X			4.1 Car platform guard	X		
2.32 (H) Control valve	X			4.2 Hoist-way doors	X		
2.33 (H) Tanks	X			4.3 Vision panels	X		
2.34 (H) Flexible hydraulic hose & fitting assemblies	X			4.4 Hoistway door locking devices	X		
2.35 (H) Supply line & shutoff valve	X			4.5 Access to hoist -way	X		
2.36 (H) Hydraulic cylinders	X			4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS006121	Report Number: 4640765
-----------------------------	------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation		X	
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
1.6		PROVIDE ADA TELEPHONE
2.1		Machine room door is required to be self-locking
2.1		machine room door is required to be self-closing
2.3		PROVIDE GUARD ON LIGHTS
2.5		Remove non-elevator related materials from machine/control room/space
2.11		Provide a car light disconnect
2.11		Label disconnect with use and fed from data
6.1		Provide keys for fireman's service

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	400 HIGH
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Hydraulic - Elevator or Dumbwaiter**

Date of Inspection: 07/17/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit: 20-175	Report Number: 4640703

Building Location and Unit Information

Building Name:	DFA NEW CAPITOL BUILDING	MS Unit ID Number:	MS006119	Unit Designation:	PASSENGER 2
Address:	400 HIGH STREET	Manufacturer:	MCE	Installed Year:	2021
City, State, Zip:	JACKSON MS 39201	Speed:	200 fpm	Capacity:	2200 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	4
				Openings:	4

(Continuation)

MS Unit ID Number: MS006119	Report Number: 4640703
------------------------------------	-------------------------------



1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1 Door reopening device	X			2.38 (H) Roped water hydraulic elevators	X		
1.2 Stop switches	X			2.39 (H) Low oil protection	X		
1.3 Operating control devices	X			2.40 Maintenance records	X		
1.4 Sills & car floor	X			2.41 Static control	X		
1.5 Car lighting & receptacles	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.6 Car emergency signal-lighting	X			3.1 Top-of-car stop switch	X		
1.7 Car door or gate	X			3.2 Car top light & outlet	X		
1.8 Door closing force	X			3.3 Top-of-car operating device	X		
1.9 Power closing of doors or gates	X			3.4 Clearance, refuge space standard railing	X		
1.10 Power opening of doors or gates	X			3.5 Normal terminal stopping devices	X		
1.11 Car vision panels & glass car doors	X			3.6 Final & emergency terminal stopping devices	X		
1.12 Car enclosure	X			3.7 Car leveling & anti-creep devices	X		
1.13 Emergency exit	X			3.8 Top emergency exit	X		
1.14 Ventilation	X			3.9 Floor & emergency identification numbering	X		
1.15 Signs & operating device symbols	X			3.10 Hoist-way construction	X		
1.16 Related load, platform area, & data plate	X			3.11 Hoist-way smoke control (IDPH only)	X		
1.17 Standby power operation	X			3.12 Pipes, wiring & ducts	X		
1.18 Restricted opening of car or hoist-way doors	X			3.13 Windows, projections, recesses, & setbacks	X		
1.19 Car ride	X			3.14 Hoist-way clearances	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.15 Multiple hoist-ways	X		
2.1 Access to Machine Space		X		3.16 Traveling cables & junction boxes	X		
2.2 Headroom	X			3.17 Door & gate equipment	X		
2.3 Lighting & receptacles	X			3.18 Car frame & stiles	X		
2.4 Machine space	X			3.19 Guide rails fastening & equipment	X		
2.5 Housekeeping		X		3.20 Governor rope	X		
2.6 Ventilation	X			3.21 Governor releasing carrier	X		
2.7 Fire extinguisher	X			3.22 Wire rope fastening & hitch plate	X		
2.8 Pipes, wiring, & ducts	X			3.23 Suspension rope	X		
2.9 Guarding of exposed auxiliary equipment	X			3.27 Crosshead data plate & rope data tags	X		
2.10 Numbering of elevators, machines, disconnects	X			3.28 Counterweight & counterweight bu er	X		
2.11 Disconnecting means & control	X			3.29 Counterweight safeties	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.30 (H) Speed test	X		
2.13 Governor, over-speed switch, & seal	X			3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.14 Code data plate	X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.30 (H) Hydraulic power unit	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A
2.31 (H) Relief valves	X			4.1 Car platform guard	X		
2.32 (H) Control valve	X			4.2 Hoist-way doors	X		
2.33 (H) Tanks	X			4.3 Vision panels	X		
2.34 (H) Flexible hydraulic hose & fitting assemblies	X			4.4 Hoistway door locking devices	X		
2.35 (H) Supply line & shutoff valve	X			4.5 Access to hoist -way	X		
2.36 (H) Hydraulic cylinders	X			4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS006119	Report Number: 4640703
-----------------------------	------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
2.1		Machine room door is required to be self-locking
2.5		Remove non-elevator related materials from machine/control room/space

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	400 HIGH
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	 

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Hydraulic - Elevator or Dumbwaiter**

Date of Inspection: 07/17/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4640807

Building Location and Unit Information

Building Name:	DFA NEW CAPITOL BUILDING	MS Unit ID Number:	MS006122	Unit Designation:	SERVICE (PRINT)
Address:	400 HIGH STREET	Manufacturer:	Otis	Installed Year:	1960
City, State, Zip:	JACKSON MS 39201	Speed:	100 fpm	Capacity:	1500 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	2
				Openings:	2

(Continuation)

MS Unit ID Number: MS006122	Report Number: 4640807
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1 Door reopening device	X			2.38 (H) Roped water hydraulic elevators	X		
1.2 Stop switches	X			2.39 (H) Low oil protection	X		
1.3 Operating control devices	X			2.40 Maintenance records	X		
1.4 Sills & car floor	X			2.41 Static control	X		
1.5 Car lighting & receptacles	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.6 Car emergency signal-lighting		X		3.1 Top-of-car stop switch	X		
1.7 Car door or gate	X			3.2 Car top light & outlet	X		
1.8 Door closing force	X			3.3 Top-of-car operating device		X	
1.9 Power closing of doors or gates	X			3.4 Clearance, refuge space standard railing	X		
1.10 Power opening of doors or gates	X			3.5 Normal terminal stopping devices	X		
1.11 Car vision panels & glass car doors	X			3.6 Final & emergency terminal stopping devices	X		
1.12 Car enclosure	X			3.7 Car leveling & anti-creep devices	X		
1.13 Emergency exit	X			3.8 Top emergency exit	X		
1.14 Ventilation	X			3.9 Floor & emergency identification numbering	X		
1.15 Signs & operating device symbols	X			3.10 Hoist-way construction	X		
1.16 Related load, platform area, & data plate	X			3.11 Hoist-way smoke control (IDPH only)	X		
1.17 Standby power operation	X			3.12 Pipes, wiring & ducts	X		
1.18 Restricted opening of car or hoist-way doors		X		3.13 Windows, projections, recesses, & setbacks	X		
1.19 Car ride	X			3.14 Hoist-way clearances	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.15 Multiple hoist-ways	X		
2.1 Access to Machine Space	X			3.16 Traveling cables & junction boxes	X		
2.2 Headroom	X			3.17 Door & gate equipment	X		
2.3 Lighting & receptacles	X			3.18 Car frame & stiles	X		
2.4 Machine space		X		3.19 Guide rails fastening & equipment	X		
2.5 Housekeeping		X		3.20 Governor rope	X		
2.6 Ventilation	X			3.21 Governor releasing carrier	X		
2.7 Fire extinguisher		X		3.22 Wire rope fastening & hitch plate	X		
2.8 Pipes, wiring, & ducts	X			3.23 Suspension rope	X		
2.9 Guarding of exposed auxiliary equipment	X			3.27 Crosshead data plate & rope data tags	X		
2.10 Numbering of elevators, machines, disconnects	X			3.28 Counterweight & counterweight bu er	X		
2.11 Disconnecting means & control		X		3.29 Counterweight safeties	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.30 (H) Speed test	X		
2.13 Governor, over-speed switch, & seal	X			3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.14 Code data plate	X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.30 (H) Hydraulic power unit	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A
2.31 (H) Relief valves	X			4.1 Car platform guard	X		
2.32 (H) Control valve	X			4.2 Hoist-way doors	X		
2.33 (H) Tanks	X			4.3 Vision panels	X		
2.34 (H) Flexible hydraulic hose & fitting assemblies	X			4.4 Hoistway door locking devices	X		
2.35 (H) Supply line & shutoff valve	X			4.5 Access to hoist -way	X		
2.36 (H) Hydraulic cylinders	X			4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS006122	Report Number: 4640807
------------------------------------	-------------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation		X	
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
1.6		PROVIDE ADA TELEPHONE
1.18	X	Door restriction required
2.4		PROVIDE ENCLOSURE AROUND CONTROLLER AND PUMPING UNIT
2.5		Remove non-elevator related materials from machine/control room/space
2.7		Fire extinguisher expired
2.11		Provide a car light disconnect
2.11		Label disconnect with use and fed from data
3.3	X	Top-of-car operating device required
6.1		Provide keys for fireman's service

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	400 HIGH
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Hydraulic - Elevator or Dumbwaiter**

Date of Inspection: 07/18/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649785

Building Location and Unit Information

Building Name:	DFA WILLIAM WINTER BUILDING	MS Unit ID Number:	MS006106	Unit Designation:	1
Address:	200 NORTH ST	Manufacturer:	ThyssenKrupp	Installed Year:	2001
City, State, Zip:	JACKSON MS 39201-1808	Speed:	125 fpm	Capacity:	2500 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	3
				Openings:	3

(Continuation)

MS Unit ID Number: MS006106	Report Number: 4649785
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1 Door reopening device	X			2.38 (H) Roped water hydraulic elevators	X		
1.2 Stop switches	X			2.39 (H) Low oil protection	X		
1.3 Operating control devices	X			2.40 Maintenance records	X		
1.4 Sills & car floor	X			2.41 Static control	X		
1.5 Car lighting & receptacles	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.6 Car emergency signal-lighting	X			3.1 Top-of-car stop switch	X		
1.7 Car door or gate	X			3.2 Car top light & outlet	X		
1.8 Door closing force	X			3.3 Top-of-car operating device	X		
1.9 Power closing of doors or gates	X			3.4 Clearance, refuge space standard railing	X		
1.10 Power opening of doors or gates	X			3.5 Normal terminal stopping devices	X		
1.11 Car vision panels & glass car doors	X			3.6 Final & emergency terminal stopping devices	X		
1.12 Car enclosure	X			3.7 Car leveling & anti-creep devices	X		
1.13 Emergency exit	X			3.8 Top emergency exit	X		
1.14 Ventilation	X			3.9 Floor & emergency identification numbering	X		
1.15 Signs & operating device symbols	X			3.10 Hoist-way construction	X		
1.16 Related load, platform area, & data plate	X			3.11 Hoist-way smoke control (IDPH only)	X		
1.17 Standby power operation	X			3.12 Pipes, wiring & ducts	X		
1.18 Restricted opening of car or hoist-way doors		X		3.13 Windows, projections, recesses, & setbacks	X		
1.19 Car ride	X			3.14 Hoist-way clearances	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.15 Multiple hoist-ways	X		
2.1 Access to Machine Space	X			3.16 Traveling cables & junction boxes	X		
2.2 Headroom	X			3.17 Door & gate equipment	X		
2.3 Lighting & receptacles		X		3.18 Car frame & stiles	X		
2.4 Machine space	X			3.19 Guide rails fastening & equipment	X		
2.5 Housekeeping	X			3.20 Governor rope	X		
2.6 Ventilation	X			3.21 Governor releasing carrier	X		
2.7 Fire extinguisher	X			3.22 Wire rope fastening & hitch plate	X		
2.8 Pipes, wiring, & ducts	X			3.23 Suspension rope	X		
2.9 Guarding of exposed auxiliary equipment	X			3.27 Crosshead data plate & rope data tags	X		
2.10 Numbering of elevators, machines, disconnects	X			3.28 Counterweight & counterweight bu er	X		
2.11 Disconnecting means & control	X			3.29 Counterweight safeties	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.30 (H) Speed test	X		
2.13 Governor, over-speed switch, & seal	X			3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.14 Code data plate	X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.30 (H) Hydraulic power unit	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A
2.31 (H) Relief valves	X			4.1 Car platform guard	X		
2.32 (H) Control valve	X			4.2 Hoist-way doors	X		
2.33 (H) Tanks	X			4.3 Vision panels	X		
2.34 (H) Flexible hydraulic hose & fitting assemblies	X			4.4 Hoistway door locking devices	X		
2.35 (H) Supply line & shutoff valve	X			4.5 Access to hoist -way	X		
2.36 (H) Hydraulic cylinders	X			4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS006106	Report Number: 4649785
------------------------------------	-------------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
1.18	X	Door restriction required
2.3		PROVIDE GUARD ON LIGHTING
5.1		FILL IN VOID AROUND JACK ASSEMBLY

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	501 N WEST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Hydraulic - Elevator or Dumbwaiter**

Date of Inspection: 07/18/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649787

Building Location and Unit Information

Building Name:	DFA WILLIAM WINTER BUILDING	MS Unit ID Number:	MS006107	Unit Designation:	2
Address:	200 NORTH ST	Manufacturer:	ThyssenKrupp	Installed Year:	2001
City, State, Zip:	JACKSON MS 39201-1808	Speed:	150 fpm	Capacity:	4500 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	5
				Openings:	5

(Continuation)

MS Unit ID Number: MS006107	Report Number: 4649787
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1 Door reopening device	X			2.38 (H) Roped water hydraulic elevators	X		
1.2 Stop switches	X			2.39 (H) Low oil protection	X		
1.3 Operating control devices	X			2.40 Maintenance records	X		
1.4 Sills & car floor	X			2.41 Static control	X		
1.5 Car lighting & receptacles	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.6 Car emergency signal-lighting	X			3.1 Top-of-car stop switch	X		
1.7 Car door or gate	X			3.2 Car top light & outlet	X		
1.8 Door closing force	X			3.3 Top-of-car operating device	X		
1.9 Power closing of doors or gates	X			3.4 Clearance, refuge space standard railing		X	
1.10 Power opening of doors or gates	X			3.5 Normal terminal stopping devices	X		
1.11 Car vision panels & glass car doors	X			3.6 Final & emergency terminal stopping devices	X		
1.12 Car enclosure	X			3.7 Car leveling & anti-creep devices	X		
1.13 Emergency exit	X			3.8 Top emergency exit	X		
1.14 Ventilation	X			3.9 Floor & emergency identification numbering	X		
1.15 Signs & operating device symbols	X			3.10 Hoist-way construction	X		
1.16 Related load, platform area, & data plate	X			3.11 Hoist-way smoke control (IDPH only)	X		
1.17 Standby power operation	X			3.12 Pipes, wiring & ducts	X		
1.18 Restricted opening of car or hoist-way doors		X		3.13 Windows, projections, recesses, & setbacks	X		
1.19 Car ride	X			3.14 Hoist-way clearances	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.15 Multiple hoist-ways	X		
2.1 Access to Machine Space	X			3.16 Traveling cables & junction boxes	X		
2.2 Headroom	X			3.17 Door & gate equipment	X		
2.3 Lighting & receptacles	X			3.18 Car frame & stiles	X		
2.4 Machine space	X			3.19 Guide rails fastening & equipment	X		
2.5 Housekeeping	X			3.20 Governor rope	X		
2.6 Ventilation	X			3.21 Governor releasing carrier	X		
2.7 Fire extinguisher	X			3.22 Wire rope fastening & hitch plate	X		
2.8 Pipes, wiring, & ducts	X			3.23 Suspension rope	X		
2.9 Guarding of exposed auxiliary equipment	X			3.27 Crosshead data plate & rope data tags	X		
2.10 Numbering of elevators, machines, disconnects	X			3.28 Counterweight & counterweight bu er	X		
2.11 Disconnecting means & control	X			3.29 Counterweight safeties	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.30 (H) Speed test	X		
2.13 Governor, over-speed switch, & seal	X			3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.14 Code data plate	X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.30 (H) Hydraulic power unit	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A
2.31 (H) Relief valves	X			4.1 Car platform guard	X		
2.32 (H) Control valve	X			4.2 Hoist-way doors	X		
2.33 (H) Tanks	X			4.3 Vision panels	X		
2.34 (H) Flexible hydraulic hose & fitting assemblies	X			4.4 Hoistway door locking devices	X		
2.35 (H) Supply line & shutoff valve	X			4.5 Access to hoist -way	X		
2.36 (H) Hydraulic cylinders	X			4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS006107	Report Number: 4649787
------------------------------------	-------------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
1.18	X	Door restriction required
3.4		Provide standard railing on the car-top that meets the code
5.1	X	Repair/provide pit ladder
5.1		Pit light switch is required to be reachable from the access point and adjacent to pit ladder

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	501 N WEST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Hydraulic - Elevator or Dumbwaiter**

Date of Inspection: 07/18/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649788

Building Location and Unit Information

Building Name:	DFA WILLIAM WINTER BUILDING	MS Unit ID Number:	MS006108	Unit Designation:	3
Address:	200 NORTH ST	Manufacturer:	ThyssenKrupp	Installed Year:	2001
City, State, Zip:	JACKSON MS 39201-1808	Speed:	150 fpm	Capacity:	4500 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	5
				Openings:	5

(Continuation)

MS Unit ID Number: MS006108	Report Number: 4649788
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR				Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1	Door reopening device			X			2.38 (H) Roped water hydraulic elevators	X		
1.2	Stop switches			X			2.39 (H) Low oil protection	X		
1.3	Operating control devices			X			2.40 Maintenance records	X		
1.4	Sills & car floor			X			2.41 Static control	X		
1.5	Car lighting & receptacles			X			3. ELEVATOR TOP OF CAR			
1.6	Car emergency signal-lighting			X			Pass	Fail	N/A	
1.7	Car door or gate			X			3.1 Top-of-car stop switch	X		
1.8	Door closing force			X			3.2 Car top light & outlet	X		
1.9	Power closing of doors or gates			X			3.3 Top-of-car operating device	X		
1.10	Power opening of doors or gates			X			3.4 Clearance, refuge space standard railing		X	
1.11	Car vision panels & glass car doors			X			3.5 Normal terminal stopping devices	X		
1.12	Car enclosure			X			3.6 Final & emergency terminal stopping devices	X		
1.13	Emergency exit			X			3.7 Car leveling & anti-creep devices	X		
1.14	Ventilation			X			3.8 Top emergency exit	X		
1.15	Signs & operating device symbols			X			3.9 Floor & emergency identification numbering	X		
1.16	Related load, platform area, & data plate			X			3.10 Hoist-way construction	X		
1.17	Standby power operation			X			3.11 Hoist-way smoke control (IDPH only)	X		
1.18	Restricted opening of car or hoist-way doors				X		3.12 Pipes, wiring & ducts	X		
1.19	Car ride			X			3.13 Windows, projections, recesses, & setbacks	X		
2. ELEVATOR MACHINE ROOM				Pass	Fail	N/A	3.14 Hoist-way clearances	X		
2.1	Access to Machine Space			X			3.15 Multiple hoist-ways	X		
2.2	Headroom			X			3.16 Traveling cables & junction boxes	X		
2.3	Lighting & receptacles			X			3.17 Door & gate equipment	X		
2.4	Machine space			X			3.18 Car frame & stiles	X		
2.5	Housekeeping			X			3.19 Guide rails fastening & equipment	X		
2.6	Ventilation			X			3.20 Governor rope	X		
2.7	Fire extinguisher			X			3.21 Governor releasing carrier	X		
2.8	Pipes, wiring, & ducts			X			3.22 Wire rope fastening & hitch plate	X		
2.9	Guarding of exposed auxiliary equipment			X			3.23 Suspension rope	X		
2.10	Numbering of elevators, machines, disconnects			X			3.27 Crosshead data plate & rope data tags	X		
2.11	Disconnecting means & control			X			3.28 Counterweight & counterweight bu er	X		
2.12	Controller wiring, fuses, grounding, etc.			X			3.29 Counterweight safeties	X		
2.13	Governor, over-speed switch, & seal			X			3.30 (H) Speed test	X		
2.14	Code data plate			X			3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.30	(H) Hydraulic power unit			X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.31	(H) Relief valves			X			4. ELEVATOR OUTSIDE HOIST-WAY			
2.32	(H) Control valve			X			Pass	Fail	N/A	
2.33	(H) Tanks			X			4.1 Car platform guard	X		
2.34	(H) Flexible hydraulic hose & fitting assemblies			X			4.2 Hoist-way doors	X		
2.35	(H) Supply line & shutoff valve			X			4.3 Vision panels	X		
2.36	(H) Hydraulic cylinders			X			4.4 Hoistway door locking devices	X		
							4.5 Access to hoist -way	X		
							4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS006108	Report Number: 4649788
------------------------------------	-------------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
1.18	X	Door restriction required
3.4		Provide standard railing on the car-top that meets the code
5.1		Pit light switch is required to be reachable from the access point and adjacent to pit ladder
5.1		REPAIR PIT LIGHTING

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	501 N WEST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Traction - Elevator / Dumbwaiter**

Date of Inspection: 07/19/2023	Conveyance Type: Passenger Elevator		
Inspection Type: <input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4650003	

Building Location and Unit Information

Building Name:	DFA WOOLFOLK BUILDING	MS Unit ID Number:	MS006085	Unit Designation:	1
Address:	501 N WEST ST	Manufacturer:	ThyssenKrupp	Installed Year:	2018
City, State, Zip:	JACKSON MS 39201-1001	Speed:	700 fpm	Capacity:	3000 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	16
				Openings:	16

(Continuation)

MS Unit ID Number: MS006085	Report Number: 4650003
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device	X			2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting	X			2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records	X		
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing	X		
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors	X			3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space	X			3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles	X			3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control	X			3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23 Suspension rope	X		
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & deflector sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A

MS Unit ID Number: MS006085	Report Number: 4650003
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
----------	--------	---------

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	501 N WEST ST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEY

Commissioner of Insurance
State Fire Marshal

MARK HAIRE

Deputy Commissioner of Insurance



MAILING ADDRESS:

P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474

MISSISSIPPI INSURANCE DEPARTMENT

ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201

Periodic - Traction - Elevator / Dumbwaiter

Date of Inspection: 07/19/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4650005

Building Location and Unit Information

Building Name:	DFA WOOLFOLK BUILDING	MS Unit ID Number:	MS006086	Unit Designation:	2
Address:	501 N WEST ST	Manufacturer:	ThyssenKrupp	Installed Year:	2018
City, State, Zip:	JACKSON MS 39201-1001	Speed:	700 fpm	Capacity:	3000 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	16
				Openings:	16

(Continuation)

MS Unit ID Number: MS006086	Report Number: 4650005
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device	X			2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting	X			2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records	X		
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing	X		
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors	X			3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space	X			3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles	X			3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control	X			3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23 Suspension rope	X		
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & de ctor sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A

MS Unit ID Number: MS006086	Report Number: 4650005
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
----------	--------	---------

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	501 N WEST ST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Traction - Elevator / Dumbwaiter**

Date of Inspection: 07/19/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4650009

Building Location and Unit Information

Building Name:	DFA WOOLFOLK BUILDING	MS Unit ID Number:	MS006087	Unit Designation:	3
Address:	501 N WEST ST	Manufacturer:	ThyssenKrupp	Installed Year:	2018
City, State, Zip:	JACKSON MS 39201-1001	Speed:	700 fpm	Capacity:	3000 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	16
				Openings:	16

(Continuation)

MS Unit ID Number: MS006087	Report Number: 4650009
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR				Pass	Fail	N/A	2.22 (T) Motor generator				X		
1.1	Door reopening device			X			2.23	(T) Absorption of regenerated power			X		
1.2	Stop switches			X			2.24	(T) AC drives from a DC source			X		
1.3	Operating control devices			X			2.25	(T) Traction sheaves			X		
1.4	Sills & car floor			X			2.26	(T) Secondary & deflector sheaves			X		
1.5	Car lighting & receptacles			X			2.27	(T) Rope fastenings			X		
1.6	Car emergency signal-lighting			X			2.28	(T) Terminal stopping devices			X		
1.7	Car door or gate			X			2.29	(T) Car & counterweight safeties			X		
1.8	Door closing force			X			2.40	Maintenance records			X		
1.9	Power closing of doors or gates			X			2.41	Static control			X		
1.10	Power opening of doors or gates			X			3. ELEVATOR TOP OF CAR				Pass	Fail	N/A
1.11	Car vision panels & glass car doors			X			3.1	Top-of-car stop switch			X		
1.12	Car enclosure			X			3.2	Car top light & outlet			X		
1.13	Emergency exit			X			3.3	Top-of-car operating device			X		
1.14	Ventilation			X			3.4	Clearance, refuge space standard railing			X		
1.15	Signs & operating device symbols			X			3.5	Normal terminal stopping devices			X		
1.16	Related load, platform area, & data plate			X			3.6	Final & emergency terminal stopping devices			X		
1.17	Standby power operation			X			3.7	Car leveling & anti-creep devices			X		
1.18	Restricted opening of car or hoist-way doors			X			3.8	Top emergency exit			X		
1.19	Car ride			X			3.9	Floor & emergency identification numbering			X		
2. ELEVATOR MACHINE ROOM				Pass	Fail	N/A	3.10	Hoist-way construction			X		
2.1	Access to Machine Space			X			3.11	Hoist-way smoke control (IDPH only)			X		
2.2	Headroom			X			3.12	Pipes, wiring & ducts			X		
2.3	Lighting & receptacles			X			3.13	Windows, projections, recesses, & setbacks			X		
2.4	Machine space			X			3.14	Hoist-way clearances			X		
2.5	Housekeeping			X			3.15	Multiple hoist-ways			X		
2.6	Ventilation			X			3.16	Traveling cables & junction boxes			X		
2.7	Fire extinguisher			X			3.17	Door & gate equipment			X		
2.8	Pipes, wiring, & ducts			X			3.18	Car frame & stiles			X		
2.9	Guarding of exposed auxiliary equipment			X			3.19	Guide rails fastening & equipment			X		
2.10	Numbering of elevators, machines, disconnects			X			3.20	Governor rope			X		
2.11	Disconnecting means & control			X			3.21	Governor releasing carrier			X		
2.12	Controller wiring, fuses, grounding, etc.			X			3.22	Wire rope fastening & hitch plate			X		
2.13	Governor, over-speed switch, & seal			X			3.23	Suspension rope			X		
2.14	Code data plate			X			3.24	(T) Top counterweight clearance			X		
2.15	(T) Static control			X			3.25	(T) Car, overhead, & de ctor sheaves			X		
2.16	(T) Overhead beam & fastenings			X			3.26	(T) Broken rope, chain, or tape switch			X		
2.17	(T) Drive machine brake			X			3.27	Crosshead data plate & rope data tags			X		
2.18	(T) Traction drive machines			X			3.28	Counterweight & counterweight buffer			X		
2.19	(T) Gears, bearings, & flexible coupling			X			3.29	Counterweight safeties			X		
2.20	(T) Winding drum mach & slack cable dev			X			3.33	(T) Compensating ropes & chains			X		
2.21	(T) Belt or chain-drive machine			X			4. ELEVATOR OUTSIDE HOIST-WAY				Pass	Fail	N/A

MS Unit ID Number: MS006087	Report Number: 4650009
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
----------	--------	---------

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	501 N WEST ST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Traction - Elevator / Dumbwaiter**

Date of Inspection: 07/19/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4650010

Building Location and Unit Information

Building Name:	DFA WOOLFOLK BUILDING	MS Unit ID Number:	MS006088	Unit Designation:	4
Address:	501 N WEST ST	Manufacturer:	ThyssenKrupp	Installed Year:	2001
City, State, Zip:	JACKSON MS 39201-1001	Speed:	700 fpm	Capacity:	3000 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	16
				Openings:	15

(Continuation)

MS Unit ID Number: MS006088	Report Number: 4650010
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device	X			2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting	X			2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records	X		
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing	X		
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors	X			3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space	X			3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles	X			3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control	X			3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23 Suspension rope	X		
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & de ctor sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A

MS Unit ID Number: MS006088	Report Number: 4650010
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
----------	--------	---------

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	501 N WEST ST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEY

Commissioner of Insurance
State Fire Marshal

MARK HAIRE

Deputy Commissioner of Insurance



MAILING ADDRESS:

P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474

MISSISSIPPI INSURANCE DEPARTMENT

ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201

Periodic - Traction - Elevator / Dumbwaiter

Date of Inspection: 07/19/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4650011

Building Location and Unit Information

Building Name:	DFA WOOLFOLK BUILDING	MS Unit ID Number:	MS006089	Unit Designation:	5
Address:	501 N WEST ST	Manufacturer:	ThyssenKrupp	Installed Year:	2001
City, State, Zip:	JACKSON MS 39201-1001	Speed:	700 fpm	Capacity:	3000 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	16
				Openings:	15

(Continuation)

MS Unit ID Number: MS006089	Report Number: 4650011
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device	X			2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting	X			2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records	X		
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing	X		
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors	X			3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space	X			3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles	X			3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes		X	
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control	X			3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23 Suspension rope	X		
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & de ctor sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A

MS Unit ID Number: MS006089	Report Number: 4650011
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
3.16		Repair/replace travel cable due to damage and/or breakage of cable insulation

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	501 N WEST ST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Traction - Elevator / Dumbwaiter**

Date of Inspection: 07/19/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4650012

Building Location and Unit Information

Building Name:	DFA WOOLFOLK BUILDING	MS Unit ID Number:	MS006090	Unit Designation:	6
Address:	501 N WEST ST	Manufacturer:	ThyssenKrupp	Installed Year:	2001
City, State, Zip:	JACKSON MS 39201-1001	Speed:	700 fpm	Capacity:	3000 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	15
				Openings:	15

(Continuation)

MS Unit ID Number: MS006090	Report Number: 4650012
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device	X			2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting	X			2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records	X		
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing	X		
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors	X			3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space	X			3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles	X			3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control	X			3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23 Suspension rope	X		
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & deflector sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A

MS Unit ID Number: MS006090	Report Number: 4650012
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
----------	--------	---------

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	501 N WEST ST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Traction - Elevator / Dumbwaiter**

Date of Inspection: 07/19/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4650013

Building Location and Unit Information

Building Name:	DFA WOOLFOLK BUILDING	MS Unit ID Number:	MS100078	Unit Designation:	1 BASEMENT
Address:	501 N WEST ST	Manufacturer:	ThyssenKrupp	Installed Year:	2020
City, State, Zip:	JACKSON MS 39201-1001	Speed:	200 fpm	Capacity:	2500 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	4
				Openings:	4

(Continuation)

MS Unit ID Number: MS100078	Report Number: 4650013
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR				Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1	Door reopening device			X			2.23 (T) Absorption of regenerated power	X		
1.2	Stop switches			X			2.24 (T) AC drives from a DC source	X		
1.3	Operating control devices			X			2.25 (T) Traction sheaves	X		
1.4	Sills & car floor			X			2.26 (T) Secondary & deflector sheaves	X		
1.5	Car lighting & receptacles			X			2.27 (T) Rope fastenings	X		
1.6	Car emergency signal-lighting			X			2.28 (T) Terminal stopping devices	X		
1.7	Car door or gate			X			2.29 (T) Car & counterweight safeties	X		
1.8	Door closing force			X			2.40 Maintenance records	X		
1.9	Power closing of doors or gates			X			2.41 Static control	X		
1.10	Power opening of doors or gates			X			3. ELEVATOR TOP OF CAR			
1.11	Car vision panels & glass car doors			X			3.1 Top-of-car stop switch	X	Pass	Fail N/A
1.12	Car enclosure			X			3.2 Car top light & outlet	X		
1.13	Emergency exit			X			3.3 Top-of-car operating device	X		
1.14	Ventilation			X			3.4 Clearance, refuge space standard railing	X		
1.15	Signs & operating device symbols			X			3.5 Normal terminal stopping devices	X		
1.16	Related load, platform area, & data plate			X			3.6 Final & emergency terminal stopping devices	X		
1.17	Standby power operation			X			3.7 Car leveling & anti-creep devices	X		
1.18	Restricted opening of car or hoist-way doors			X			3.8 Top emergency exit	X		
1.19	Car ride			X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM				Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1	Access to Machine Space			X			3.11 Hoist-way smoke control (IDPH only)	X		
2.2	Headroom			X			3.12 Pipes, wiring & ducts	X		
2.3	Lighting & receptacles			X			3.13 Windows, projections, recesses, & setbacks	X		
2.4	Machine space			X			3.14 Hoist-way clearances	X		
2.5	Housekeeping			X			3.15 Multiple hoist-ways	X		
2.6	Ventilation			X			3.16 Traveling cables & junction boxes	X		
2.7	Fire extinguisher				X		3.17 Door & gate equipment	X		
2.8	Pipes, wiring, & ducts			X			3.18 Car frame & stiles	X		
2.9	Guarding of exposed auxiliary equipment			X			3.19 Guide rails fastening & equipment	X		
2.10	Numbering of elevators, machines, disconnects			X			3.20 Governor rope	X		
2.11	Disconnecting means & control			X			3.21 Governor releasing carrier	X		
2.12	Controller wiring, fuses, grounding, etc.			X			3.22 Wire rope fastening & hitch plate	X		
2.13	Governor, over-speed switch, & seal			X			3.23 Suspension rope	X		
2.14	Code data plate			X			3.24 (T) Top counterweight clearance	X		
2.15	(T) Static control			X			3.25 (T) Car, overhead, & de ctor sheaves	X		
2.16	(T) Overhead beam & fastenings			X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17	(T) Drive machine brake			X			3.27 Crosshead data plate & rope data tags	X		
2.18	(T) Traction drive machines			X			3.28 Counterweight & counterweight buffer	X		
2.19	(T) Gears, bearings, & flexible coupling			X			3.29 Counterweight safeties	X		
2.20	(T) Winding drum mach & slack cable dev			X			3.33 (T) Compensating ropes & chains	X		
2.21	(T) Belt or chain-drive machine			X			4. ELEVATOR OUTSIDE HOIST-WAY			
								Pass	Fail	N/A

MS Unit ID Number: MS100078	Report Number: 4650013
------------------------------------	-------------------------------


4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition	X		
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
2.7		Fire extinguisher expired

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	501 N WEST ST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Hydraulic - Elevator or Dumbwaiter**

Date of Inspection: 07/19/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4650017

Building Location and Unit Information

Building Name:	DFA WOOLFOLK BUILDING	MS Unit ID Number:	MS006094	Unit Designation:	1 ANNEX
Address:	501 N WEST ST	Manufacturer:	Schindler	Installed Year:	2001
City, State, Zip:	JACKSON MS 39201-1001	Speed:	150 fpm	Capacity:	2500 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	3
				Openings:	3

(Continuation)

MS Unit ID Number: MS006094	Report Number: 4650017
------------------------------------	-------------------------------



1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1 Door reopening device	X			2.38 (H) Roped water hydraulic elevators	X		
1.2 Stop switches	X			2.39 (H) Low oil protection	X		
1.3 Operating control devices	X			2.40 Maintenance records	X		
1.4 Sills & car floor	X			2.41 Static control	X		
1.5 Car lighting & receptacles	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.6 Car emergency signal-lighting	X			3.1 Top-of-car stop switch	X		
1.7 Car door or gate	X			3.2 Car top light & outlet	X		
1.8 Door closing force	X			3.3 Top-of-car operating device	X		
1.9 Power closing of doors or gates	X			3.4 Clearance, refuge space standard railing	X		
1.10 Power opening of doors or gates	X			3.5 Normal terminal stopping devices	X		
1.11 Car vision panels & glass car doors	X			3.6 Final & emergency terminal stopping devices	X		
1.12 Car enclosure	X			3.7 Car leveling & anti-creep devices	X		
1.13 Emergency exit	X			3.8 Top emergency exit	X		
1.14 Ventilation	X			3.9 Floor & emergency identification numbering	X		
1.15 Signs & operating device symbols	X			3.10 Hoist-way construction	X		
1.16 Related load, platform area, & data plate	X			3.11 Hoist-way smoke control (IDPH only)	X		
1.17 Standby power operation	X			3.12 Pipes, wiring & ducts	X		
1.18 Restricted opening of car or hoist-way doors		X		3.13 Windows, projections, recesses, & setbacks	X		
1.19 Car ride	X			3.14 Hoist-way clearances	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.15 Multiple hoist-ways	X		
2.1 Access to Machine Space	X			3.16 Traveling cables & junction boxes	X		
2.2 Headroom	X			3.17 Door & gate equipment	X		
2.3 Lighting & receptacles	X			3.18 Car frame & stiles	X		
2.4 Machine space	X			3.19 Guide rails fastening & equipment	X		
2.5 Housekeeping	X			3.20 Governor rope	X		
2.6 Ventilation	X			3.21 Governor releasing carrier	X		
2.7 Fire extinguisher	X			3.22 Wire rope fastening & hitch plate	X		
2.8 Pipes, wiring, & ducts	X			3.23 Suspension rope	X		
2.9 Guarding of exposed auxiliary equipment	X			3.27 Crosshead data plate & rope data tags	X		
2.10 Numbering of elevators, machines, disconnects	X			3.28 Counterweight & counterweight bu er	X		
2.11 Disconnecting means & control	X			3.29 Counterweight safeties	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.30 (H) Speed test	X		
2.13 Governor, over-speed switch, & seal	X			3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.14 Code data plate	X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.30 (H) Hydraulic power unit	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A
2.31 (H) Relief valves	X			4.1 Car platform guard	X		
2.32 (H) Control valve	X			4.2 Hoist-way doors	X		
2.33 (H) Tanks	X			4.3 Vision panels	X		
2.34 (H) Flexible hydraulic hose & fitting assemblies	X			4.4 Hoistway door locking devices	X		
2.35 (H) Supply line & shutoff valve	X			4.5 Access to hoist -way	X		
2.36 (H) Hydraulic cylinders	X			4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS006094	Report Number: 4650017
------------------------------------	-------------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
1.18	X	Door restriction required
5.1	X	Pit stop switch is required to be reachable from the hoistway access point and adjacent to pit ladder
5.1		Pit light switch is required to be reachable from the access point and adjacent to pit ladder

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	501 N WEST ST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	 

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Hydraulic - Elevator or Dumbwaiter**

Date of Inspection: 07/19/2023	Conveyance Type: Passenger Elevator		
Inspection Type: <input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4650020	

Building Location and Unit Information

Building Name:	DFA WOOLFOLK BUILDING	MS Unit ID Number:	MS006095	Unit Designation:	2 ANNEX
Address:	501 N WEST ST	Manufacturer:	Schindler	Installed Year:	2001
City, State, Zip:	JACKSON MS 39201-1001	Speed:	150 fpm	Capacity:	2500 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	3
				Openings:	3

(Continuation)

MS Unit ID Number: MS006095	Report Number: 4650020
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1 Door reopening device	X			2.38 (H) Roped water hydraulic elevators	X		
1.2 Stop switches	X			2.39 (H) Low oil protection	X		
1.3 Operating control devices	X			2.40 Maintenance records	X		
1.4 Sills & car floor	X			2.41 Static control	X		
1.5 Car lighting & receptacles	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.6 Car emergency signal-lighting	X			3.1 Top-of-car stop switch	X		
1.7 Car door or gate	X			3.2 Car top light & outlet	X		
1.8 Door closing force	X			3.3 Top-of-car operating device	X		
1.9 Power closing of doors or gates	X			3.4 Clearance, refuge space standard railing	X		
1.10 Power opening of doors or gates	X			3.5 Normal terminal stopping devices	X		
1.11 Car vision panels & glass car doors	X			3.6 Final & emergency terminal stopping devices	X		
1.12 Car enclosure	X			3.7 Car leveling & anti-creep devices	X		
1.13 Emergency exit	X			3.8 Top emergency exit	X		
1.14 Ventilation	X			3.9 Floor & emergency identification numbering	X		
1.15 Signs & operating device symbols	X			3.10 Hoist-way construction	X		
1.16 Related load, platform area, & data plate	X			3.11 Hoist-way smoke control (IDPH only)	X		
1.17 Standby power operation	X			3.12 Pipes, wiring & ducts	X		
1.18 Restricted opening of car or hoist-way doors		X		3.13 Windows, projections, recesses, & setbacks	X		
1.19 Car ride	X			3.14 Hoist-way clearances	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.15 Multiple hoist-ways	X		
2.1 Access to Machine Space	X			3.16 Traveling cables & junction boxes	X		
2.2 Headroom	X			3.17 Door & gate equipment	X		
2.3 Lighting & receptacles	X			3.18 Car frame & stiles	X		
2.4 Machine space	X			3.19 Guide rails fastening & equipment	X		
2.5 Housekeeping	X			3.20 Governor rope	X		
2.6 Ventilation	X			3.21 Governor releasing carrier	X		
2.7 Fire extinguisher	X			3.22 Wire rope fastening & hitch plate	X		
2.8 Pipes, wiring, & ducts	X			3.23 Suspension rope	X		
2.9 Guarding of exposed auxiliary equipment	X			3.27 Crosshead data plate & rope data tags	X		
2.10 Numbering of elevators, machines, disconnects	X			3.28 Counterweight & counterweight bu er	X		
2.11 Disconnecting means & control	X			3.29 Counterweight safeties	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.30 (H) Speed test	X		
2.13 Governor, over-speed switch, & seal	X			3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.14 Code data plate	X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.30 (H) Hydraulic power unit	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A
2.31 (H) Relief valves	X			4.1 Car platform guard	X		
2.32 (H) Control valve	X			4.2 Hoist-way doors	X		
2.33 (H) Tanks	X			4.3 Vision panels	X		
2.34 (H) Flexible hydraulic hose & fitting assemblies	X			4.4 Hoistway door locking devices	X		
2.35 (H) Supply line & shutoff valve	X			4.5 Access to hoist -way	X		
2.36 (H) Hydraulic cylinders	X			4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS006095	Report Number: 4650020
------------------------------------	-------------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
1.18	X	Door restriction required
5.1	X	Repair/provide pit ladder
5.1		PROVIDE NON COMBUSTIBLE SUMP HOLE COVER

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	501 N WEST ST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Hydraulic - Elevator or Dumbwaiter**

Date of Inspection: 07/19/2023	Conveyance Type: Passenger Elevator		
Inspection Type: <input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649990	

Building Location and Unit Information

Building Name:	DFA WOOLFOLK BUILDING	MS Unit ID Number:	MS006092	Unit Designation:	EXPRESS N.
Address:	501 N WEST ST	Manufacturer:	Schindler	Installed Year:	2001
City, State, Zip:	JACKSON MS 39201-1001	Speed:	150 fpm	Capacity:	2500 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	5
				Openings:	5

(Continuation)

MS Unit ID Number: MS006092	Report Number: 4649990
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR				Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1	Door reopening device			X			2.38 (H) Roped water hydraulic elevators	X		
1.2	Stop switches			X			2.39 (H) Low oil protection	X		
1.3	Operating control devices			X			2.40 Maintenance records	X		
1.4	Sills & car floor			X			2.41 Static control	X		
1.5	Car lighting & receptacles			X			3. ELEVATOR TOP OF CAR			
1.6	Car emergency signal-lighting			X			3.1 Top-of-car stop switch	X		
1.7	Car door or gate			X			3.2 Car top light & outlet	X		
1.8	Door closing force			X			3.3 Top-of-car operating device	X		
1.9	Power closing of doors or gates			X			3.4 Clearance, refuge space standard railing	X		
1.10	Power opening of doors or gates			X			3.5 Normal terminal stopping devices	X		
1.11	Car vision panels & glass car doors			X			3.6 Final & emergency terminal stopping devices	X		
1.12	Car enclosure			X			3.7 Car leveling & anti-creep devices	X		
1.13	Emergency exit			X			3.8 Top emergency exit	X		
1.14	Ventilation			X			3.9 Floor & emergency identification numbering	X		
1.15	Signs & operating device symbols			X			3.10 Hoist-way construction	X		
1.16	Related load, platform area, & data plate			X			3.11 Hoist-way smoke control (IDPH only)	X		
1.17	Standby power operation			X			3.12 Pipes, wiring & ducts	X		
1.18	Restricted opening of car or hoist-way doors				X		3.13 Windows, projections, recesses, & setbacks	X		
1.19	Car ride			X			3.14 Hoist-way clearances	X		
2. ELEVATOR MACHINE ROOM				Pass	Fail	N/A	3.15 Multiple hoist-ways	X		
2.1	Access to Machine Space			X			3.16 Traveling cables & junction boxes	X		
2.2	Headroom			X			3.17 Door & gate equipment	X		
2.3	Lighting & receptacles			X			3.18 Car frame & stiles	X		
2.4	Machine space			X			3.19 Guide rails fastening & equipment	X		
2.5	Housekeeping			X			3.20 Governor rope	X		
2.6	Ventilation			X			3.21 Governor releasing carrier	X		
2.7	Fire extinguisher			X			3.22 Wire rope fastening & hitch plate	X		
2.8	Pipes, wiring, & ducts				X		3.23 Suspension rope	X		
2.9	Guarding of exposed auxiliary equipment			X			3.27 Crosshead data plate & rope data tags	X		
2.10	Numbering of elevators, machines, disconnects			X			3.28 Counterweight & counterweight bu er	X		
2.11	Disconnecting means & control				X		3.29 Counterweight safeties	X		
2.12	Controller wiring, fuses, grounding, etc.			X			3.30 (H) Speed test	X		
2.13	Governor, over-speed switch, & seal			X			3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.14	Code data plate			X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.30	(H) Hydraulic power unit			X			4. ELEVATOR OUTSIDE HOIST-WAY			
2.31	(H) Relief valves			X			4.1 Car platform guard	X		
2.32	(H) Control valve			X			4.2 Hoist-way doors	X		
2.33	(H) Tanks			X			4.3 Vision panels	X		
2.34	(H) Flexible hydraulic hose & fitting assemblies			X			4.4 Hoistway door locking devices	X		
2.35	(H) Supply line & shutoff valve			X			4.5 Access to hoist -way	X		
2.36	(H) Hydraulic cylinders			X			4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS006092	Report Number: 4649990
------------------------------------	-------------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
1.18	X	Door restriction required
2.8	X	Provide heat detector within 2' of sprinkler head to initiate power shunt prior to application of sprinkler water in machine room
2.8		PROVIDE SHUNT TRIP DISCONNECT
2.11		Provide a car light disconnect
5.1		PROVIDE NON COMBUSTIBLE SUMP HOLE COVER

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	501 N WEST ST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Hydraulic - Elevator or Dumbwaiter**

Date of Inspection: 07/19/2023		Conveyance Type: Passenger Elevator	
Inspection Type:	<input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:	Report Number: 4649987

Building Location and Unit Information

Building Name:	DFA WOOLFOLK BUILDING	MS Unit ID Number:	MS006093	Unit Designation:	EXPRESS S.
Address:	501 N WEST ST	Manufacturer:	Schindler	Installed Year:	2001
City, State, Zip:	JACKSON MS 39201-1001	Speed:	150 fpm	Capacity:	2500 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	5
				Openings:	5

(Continuation)

MS Unit ID Number: MS006093	Report Number: 4649987
------------------------------------	-------------------------------


1. ELEVATOR INSIDE OF CAR				Pass	Fail	N/A	2.37 (H) Pressure switch	X		
1.1	Door reopening device			X			2.38 (H) Roped water hydraulic elevators	X		
1.2	Stop switches			X			2.39 (H) Low oil protection	X		
1.3	Operating control devices			X			2.40 Maintenance records	X		
1.4	Sills & car floor			X			2.41 Static control	X		
1.5	Car lighting & receptacles			X			3. ELEVATOR TOP OF CAR			
1.6	Car emergency signal-lighting			X			3.1 Top-of-car stop switch	X		
1.7	Car door or gate			X			3.2 Car top light & outlet	X		
1.8	Door closing force			X			3.3 Top-of-car operating device	X		
1.9	Power closing of doors or gates			X			3.4 Clearance, refuge space standard railing	X		
1.10	Power opening of doors or gates			X			3.5 Normal terminal stopping devices	X		
1.11	Car vision panels & glass car doors			X			3.6 Final & emergency terminal stopping devices	X		
1.12	Car enclosure			X			3.7 Car leveling & anti-creep devices	X		
1.13	Emergency exit			X			3.8 Top emergency exit	X		
1.14	Ventilation			X			3.9 Floor & emergency identification numbering	X		
1.15	Signs & operating device symbols			X			3.10 Hoist-way construction	X		
1.16	Related load, platform area, & data plate			X			3.11 Hoist-way smoke control (IDPH only)	X		
1.17	Standby power operation			X			3.12 Pipes, wiring & ducts	X		
1.18	Restricted opening of car or hoist-way doors				X		3.13 Windows, projections, recesses, & setbacks	X		
1.19	Car ride			X			3.14 Hoist-way clearances	X		
2. ELEVATOR MACHINE ROOM				Pass	Fail	N/A	3.15 Multiple hoist-ways	X		
2.1	Access to Machine Space			X			3.16 Traveling cables & junction boxes	X		
2.2	Headroom			X			3.17 Door & gate equipment	X		
2.3	Lighting & receptacles			X			3.18 Car frame & stiles	X		
2.4	Machine space			X			3.19 Guide rails fastening & equipment	X		
2.5	Housekeeping			X			3.20 Governor rope	X		
2.6	Ventilation			X			3.21 Governor releasing carrier	X		
2.7	Fire extinguisher			X			3.22 Wire rope fastening & hitch plate	X		
2.8	Pipes, wiring, & ducts				X		3.23 Suspension rope	X		
2.9	Guarding of exposed auxiliary equipment			X			3.27 Crosshead data plate & rope data tags	X		
2.10	Numbering of elevators, machines, disconnects			X			3.28 Counterweight & counterweight bu er	X		
2.11	Disconnecting means & control				X		3.29 Counterweight safeties	X		
2.12	Controller wiring, fuses, grounding, etc.			X			3.30 (H) Speed test	X		
2.13	Governor, over-speed switch, & seal			X			3.31 (H) Slack rope device – roped-hydraulic elevators	X		
2.14	Code data plate			X			3.32 (H) Traveling sheave – roped hydraulic elevators	X		
2.30	(H) Hydraulic power unit			X			4. ELEVATOR OUTSIDE HOIST-WAY			
2.31	(H) Relief valves			X			4.1 Car platform guard	X		
2.32	(H) Control valve			X			4.2 Hoist-way doors	X		
2.33	(H) Tanks			X			4.3 Vision panels	X		
2.34	(H) Flexible hydraulic hose & fitting assemblies			X			4.4 Hoistway door locking devices	X		
2.35	(H) Supply line & shutoff valve			X			4.5 Access to hoist -way	X		
2.36	(H) Hydraulic cylinders			X			4.6 Power closing of hoist -way doors	X		

MS Unit ID Number: MS006093	Report Number: 4649987
------------------------------------	-------------------------------


4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.11	(H) Plunger & cylinder	X		
5.12	(H) Car buffer	X		
5.13	(H) Guiding members	X		
5.14	(H) Supply piping	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
Disclaimer		Pass	Fail	N/A

Item No.	Repeat	Comment
1.18	X	Door restriction required
2.8	X	Provide heat detector within 2' of sprinkler head to initiate power shunt prior to application of sprinkler water in machine room
2.8		PROVIDE SHUNT TRIP DISCONNECT
2.11		110v car light disconnect must be fused and lockable
5.1		PROVIDE NON COMBUSTIBLE SUMP HOLE COVER

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	501 N WEST ST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only

MIKE CHANEYCommissioner of Insurance
State Fire Marshal**MARK HAIRE**

Deputy Commissioner of Insurance

**MAILING ADDRESS:**P.O. Box 79
Jackson, MS 39205-0079
Phone: 601-359-3569
Fax: 601-359-2474**MISSISSIPPI INSURANCE DEPARTMENT**ELEVATOR SAFETY DIVISION
501 N. WEST STREET, SUITE 1001
WOOLFOLK BUILDING
JACKSON, MISSISSIPPI 39201**Periodic - Traction - Elevator / Dumbwaiter**

Date of Inspection: 07/19/2023	Conveyance Type: Freight Elevator		
Inspection Type: <input checked="" type="checkbox"/> Periodic <input type="checkbox"/> Acceptance	Permit:		Report Number: 4649996

Building Location and Unit Information

Building Name:	DFA WOOLFOLK BUILDING	MS Unit ID Number:	MS006084	Unit Designation:	FREIGHT
Address:	501 N WEST ST	Manufacturer:	Schindler	Installed Year:	2001
City, State, Zip:	JACKSON MS 39201-1001	Speed:	200 fpm	Capacity:	4000 lbs
Contact:	CAPITOL FACILITIES	Phone:	(769) 245-6329	Stops:	16
				Openings:	16

(Continuation)


MS Unit ID Number: MS006084	Report Number: 4649996
------------------------------------	-------------------------------

1. ELEVATOR INSIDE OF CAR	Pass	Fail	N/A	2.22 (T) Motor generator	X		
1.1 Door reopening device	X			2.23 (T) Absorption of regenerated power	X		
1.2 Stop switches	X			2.24 (T) AC drives from a DC source	X		
1.3 Operating control devices	X			2.25 (T) Traction sheaves	X		
1.4 Sills & car floor	X			2.26 (T) Secondary & deflector sheaves	X		
1.5 Car lighting & receptacles	X			2.27 (T) Rope fastenings	X		
1.6 Car emergency signal-lighting		X		2.28 (T) Terminal stopping devices	X		
1.7 Car door or gate	X			2.29 (T) Car & counterweight safeties	X		
1.8 Door closing force	X			2.40 Maintenance records	X		
1.9 Power closing of doors or gates	X			2.41 Static control	X		
1.10 Power opening of doors or gates	X			3. ELEVATOR TOP OF CAR	Pass	Fail	N/A
1.11 Car vision panels & glass car doors	X			3.1 Top-of-car stop switch	X		
1.12 Car enclosure	X			3.2 Car top light & outlet	X		
1.13 Emergency exit	X			3.3 Top-of-car operating device	X		
1.14 Ventilation	X			3.4 Clearance, refuge space standard railing	X		
1.15 Signs & operating device symbols	X			3.5 Normal terminal stopping devices	X		
1.16 Related load, platform area, & data plate	X			3.6 Final & emergency terminal stopping devices	X		
1.17 Standby power operation	X			3.7 Car leveling & anti-creep devices	X		
1.18 Restricted opening of car or hoist-way doors	X			3.8 Top emergency exit	X		
1.19 Car ride	X			3.9 Floor & emergency identification numbering	X		
2. ELEVATOR MACHINE ROOM	Pass	Fail	N/A	3.10 Hoist-way construction	X		
2.1 Access to Machine Space		X		3.11 Hoist-way smoke control (IDPH only)	X		
2.2 Headroom	X			3.12 Pipes, wiring & ducts	X		
2.3 Lighting & receptacles	X			3.13 Windows, projections, recesses, & setbacks	X		
2.4 Machine space	X			3.14 Hoist-way clearances	X		
2.5 Housekeeping	X			3.15 Multiple hoist-ways	X		
2.6 Ventilation	X			3.16 Traveling cables & junction boxes	X		
2.7 Fire extinguisher	X			3.17 Door & gate equipment	X		
2.8 Pipes, wiring, & ducts	X			3.18 Car frame & stiles	X		
2.9 Guarding of exposed auxiliary equipment	X			3.19 Guide rails fastening & equipment	X		
2.10 Numbering of elevators, machines, disconnects	X			3.20 Governor rope	X		
2.11 Disconnecting means & control	X			3.21 Governor releasing carrier	X		
2.12 Controller wiring, fuses, grounding, etc.	X			3.22 Wire rope fastening & hitch plate	X		
2.13 Governor, over-speed switch, & seal	X			3.23 Suspension rope	X		
2.14 Code data plate	X			3.24 (T) Top counterweight clearance	X		
2.15 (T) Static control	X			3.25 (T) Car, overhead, & de ctor sheaves	X		
2.16 (T) Overhead beam & fastenings	X			3.26 (T) Broken rope, chain, or tape switch	X		
2.17 (T) Drive machine brake	X			3.27 Crosshead data plate & rope data tags	X		
2.18 (T) Traction drive machines	X			3.28 Counterweight & counterweight buffer	X		
2.19 (T) Gears, bearings, & flexible coupling	X			3.29 Counterweight safeties	X		
2.20 (T) Winding drum mach & slack cable dev	X			3.33 (T) Compensating ropes & chains	X		
2.21 (T) Belt or chain-drive machine	X			4. ELEVATOR OUTSIDE HOIST-WAY	Pass	Fail	N/A


MS Unit ID Number: MS006084		Report Number: 4649996		
4.1	Car platform guard	X		
4.2	Hoist-way doors	X		
4.3	Vision panels	X		
4.4	Hoistway door locking devices	X		
4.5	Access to hoist -way	X		
4.6	Power closing of hoist -way doors	X		
4.7	Sequence operation	X		
4.8	Hoist -way enclosure	X		
4.9	Elevator parking devices	X		
4.10	Emergency doors in blind hoist -ways	X		
4.11	(T) Separate counterweight hoist -way	X		
4.12	Standby power selection switch	X		
5. ELEVATOR PIT		Pass	Fail	N/A
5.1	Pit access, lighting, stop switch, & condition		X	
5.2	Bottom clearance, run -by & min. refuge space	X		
5.3	(T) Final & emergency terminal stopping devices	X		
5.4	Normal terminal stopping devices	X		
5.5	Traveling cables	X		
5.6	Governor -rope tension devices	X		
5.7	Car frame & platform	X		
5.8	Car safeties & guiding members – including roped-hydraulic	X		
5.9	(T) Buffers & emergency terminal speed limiting	X		
5.10	(T) Compensating chains, ropes & sheaves	X		
6. ELEVATOR FIRE SERVICE		Pass	Fail	N/A
6.1	Phase I Operation	X		
6.2	Phase II Operation	X		
6.3	FAID (Fire Alarm Initiating Device) Operation	X		
Completion		Pass	Fail	N/A
DISCLAIMER		Pass	Fail	N/A

Item No.	Repeat	Comment
1.6		LOWER TELEPHONE TO CORRECT ADA HEIGHT
2.1		machine room door is required to be self-closing
5.1	X	Pit stop switch is required to be reachable from the hoistway access point and adjacent to pit ladder
5.1		PROVIDE NON COMBUSTIBLE SUMP HOLE COVER

Building Owner Information:

Owner Name:	CAPITOL FACILITIES
Owner Address:	501 N WEST ST
City, State, Zip:	JACKSON, MS 39201
Contact:	CAPITOL FACILITIES
Signature:	

Inspection Company & Inspector's Information:

Company Name:	BUREAU VERITAS NATIONAL ELEVATOR INSPECTION SERVICES, INC.
Street Address:	11973 WESTLINE INDUSTRIAL DR, STE 100
City, State, Zip:	SAINT LOUIS, MO 63146-3216
Inspector QEI #:	
Inspector State License #:	
Inspector's Signature:	

PASS - Meets requirement
 FAIL - Failed
 N/A - Not Applicable
 (T) - Traction elevators only
 (H) - Hydraulic elevators only