DIRECTIONS:

Use at the rate of 1 gallon of LOOP TREAT to 200 gallons of system water.

LOOP TREAT contains a pH sensitive indicator. Treatment should be added until a strong pink color is maintained. Allow LOOP TREAT to circulate in system for several days. Recheck to insure strong pink color remains.

KEEP OUT OF REACH OF CHILDREN

LOOP TREAT

03-8961-5

Manufactured for
Liquid Solutions LLC
PO Box 677
Magee, MS 39111

An All Inclusive Treatment for Hot/Chill Closed Loop Systems

For Industrial, Commercial and Institutional use only

DANGER:
May Cause Eye And Skin Burns.
Harmful if swallowed.

PRECAUTIONARY MEASURES: Contains Sodium Hydroxide. Do Not get in eyes or on skin or clothing. Avoid breathing vapor or mist. Keep container closed. Use with adequate ventilation.

FIRST AID: In case of contact flush eyes or skin with water for 15 minutes. Remove contaminated clothing. If swallowed DO NOT induce vomiting. Drink a glass of water and contact a physician immediately.

IN CASE OF SPILL: Absorb with inert material and dispose of in waste container. Flush area with water.

DIRECTIONS:

Use at the rate of 1 gallon of LOOP TREAT to 200 gallons of system water.

LOOP TREAT contains a pH sensitive indicator. Treatment should be added until a strong pink color is maintained. Allow LOOP TREAT to circulate in system for several days. Recheck to insure strong pink color remains.

KEEP OUT OF REACH OF CHILDREN

LOOP TREAT

03-8961-5

Manufactured for
Liquid Solutions LLC
PO Box 677
Magee, MS 39111

An All Inclusive Treatment for Hot/Chill Closed Loop Systems

For Industrial, Commercial and Institutional use only

DANGER:
May Cause Eye And Skin Burns.
Harmful if swallowed.

PRECAUTIONARY MEASURES: Contains Sodium Hydroxide. Do Not get in eyes or on skin or clothing. Avoid breathing vapor or mist. Keep container closed. Use with adequate ventilation.

FIRST AID: In case of contact flush eyes or skin with water for 15 minutes. Remove contaminated clothing. If swallowed DO NOT induce vomiting. Drink a glass of water and contact a physician immediately.

IN CASE OF SPILL: Absorb with inert material and dispose of in waste container. Flush area with water.