CERTIFIED®

WT-55™

Closed-System Corrosion Inhibitor

SAMPLE

Read the entire label before using this product. • Si usted no entiende esta etiqueta, pida a alguien que sepa inglés que se la explique completamente antes de usar este producto.

- **Provides corrosion protection in closed recirculating hot/chill water systems - even in systems that are not airtight**
- **Prevents exchangers and zone valves from plugging due to corrosion**
- **This product is a non-chromate inhibitor, specially formulated for corrosion inhibition in copper, steel and multi-metal systems**
- **This product is an effective corrosion inhibitor for recirculating closed loops containing water or systems that contain a 50% mixture of water with either ethylene or propylene glycol**

Suitable for use as a boiler treatment or cooling system compound where neither the treated water nor the steam produced may contact edible products in U.S. Federally inspected meat and poultry plants.

NET CONTENTS: _____

CERTIFIED LABORATORIES
A Division of NCH Corporation
P.O. Box 2493, Ft. Worth, Texas 76113-2493
www.certifiedlabs.com • ©2014 NCH Corporation

DIRECTIONS FOR USE: ATTENTION: After diluting this product as recommended, do not add any materials containing secondary amines. To do so can produce nitrosamines that may cause cancer in humans.

NOTE

1. **NOT FOR USE IN OR FOR CONTACT WITH POTABLE WATER SYSTEMS OR DOMESTIC WATER SOURCES.**
2. KEEP THE CONTAINER CLOSED WHEN NOT IN USE.
3. If the dosage is less than the capacity of the pot feeder, fill the feeder with tap water to prevent air entrapment.
4. Do not store in unlined containers or tanks. Confirm compatibility of product with the tank lining before storing in a lined tank. Undiluted product will attack soft metals such as aluminum, copper, tin, and zinc.

Hot Water Recirculating Systems

For initial and maintenance treatment, add one part product per 400 parts of water in the system.

Chill Water Recirculating Systems

For initial and maintenance treatment, add one part product per 800 parts of water in the system.

Glycol Recirculation Systems

For initial and maintenance treatment, add one part product per 100 parts of water in the system.

The treatment level should be tested with a suitable Nitrite test kit.

Consult your water treatment consultant for further instructions.

DISPOSAL
Dispose of contents and container in accordance with applicable regulations.

STORAGE: Keep from contact with clothing and other combustible materials. Store in tightly closed container. Avoid direct sunlight or high-temperature storage areas. Store in a corrosion-resistant container. Confirm compatibility of product with the tank lining before storing in a lined tank. Undiluted product will attack soft metals such as aluminum, copper, tin and zinc. Absorb spillage to prevent damage.

KEEP FROM FREEZING. If this product is stored in cold or freezing temperatures, it may separate or thicken. This will not harm the performance. Before using, warm to room temperature and stir thoroughly.

DANGER
MAY INTENSIFY FIRE; OXIDIZER • CAUSES SEVERE SKIN BURNS AND EYE DAMAGE • HARMFUL IF SWALLOWED • MAY CAUSE CANCER • SUSPECTED OF DAMAGING FERTILITY OR THE UNBORN CHILD • MAY CAUSE DAMAGE TO ORGANS THROUGH PROLONGED OR REPEATED EXPOSURE

Contains Sodium hydroxide and Sodium nitrite. Keep away from heat, sparks, open flames or hot surfaces. Take any precaution to avoid mixing with combustibles. Wear protective gloves, protective clothing, eye protection and face protection. Wash face, hands and any exposed skin thoroughly after handling. Do not breathe mist. Do not eat, drink or smoke when using this product. 6% of the mixture consists of ingredient(s) of unknown toxicity.

FIRST AID

IF ON SKIN: Immediately remove contaminated clothing and shoes. Flush affected areas with large amounts of water for 20 to 30 minutes. Get immediate medical attention. Discard clothing and shoes.

IF IN EYES: Immediately rinse the eyes with water. Remove any contact lenses and continue flushing for at least 15 minutes. Hold the eyelids apart to ensure rinsing of the entire surface of the eyes and lids with water. Get immediate medical attention.

IF INHALED: Remove person to fresh air and keep at rest in a position comfortable for breathing. If experiencing respiratory symptoms, call a physician.

IF SWALLOWED: Rinse mouth. DO NOT induce vomiting. Call a physician if unwell.

KEEP OUT OF REACH OF CHILDREN

See the Safety Data Sheet for more information.

For medical or environmental emergencies, call CHEMTREC® at 1-800-424-9300.

Not for Resale

MADE IN THE U.S.A.
0837CGBA
1M404

CSPA Product Care®

QUALITY ISO 9001 ASSURANCE

TO REORDER, Call TOLL-FREE:
1-800-527-9929
FAX: 1-800-456-0121

12049978