TOWER 1 D

COOLING WATER TREATMENT

DIRECTIONS FOR USE:

A combination scale retardant, antifoulant and corrosion inhibitor, TOWER 1 D may be fed through automatic dilution and metering equipment directly to a point of rapid circulation within the cooling water system. Dilutions of TOWER 1 D are best made with softened or low hardness water. Consult your service representative for specific recommendations.

CAUTION: CAUSES EYE AND SKIN IRRITATION. HARMFUL IF SWALLOWED. AVOID CONTACT WITH EYES AND SKIN. DO NOT TAKE INTERNALLY. CONTAINS ALKALINE SALTS AND POLYMERS.

FIRST AID:

EYES: Flush with water for 15 minutes. Get medical attention immediately.
SKIN: Flush with water for 15 minutes. Get medical attention if irritation persists.
INTERNAL: DO NOT INDUCE VOMITING. If the person is conscious, give several large glasses of water. Get medical attention immediately.
INHALATION: Remove to fresh air. Get medical attention if breathing difficulty occurs.

SPILL AND DISPOSAL:

SMALL SPILL: Flush to waste with large quantities of water.
LARGE SPILL: Completely contain all spilled material. Absorb onto inert compound and reclaim to a closed DOT approved container. Residue may be flushed to drain with large quantities of water.
DISPOSAL: Dispose of contaminated product in accordance with Federal, state and local regulations.

NET CONTENTS _____ GALLONS

FOR SECONDARY CONTAINER USE ONLY

ZEE COMPANY®
A Member of The Vincit Group
4146 South Creek Road
Chattanooga, Tennessee 37406
423-698-1401

WTD1A